

**U.S. Community Protocol  
for Accounting and Reporting of Greenhouse Gas Emissions**

**Appendix F: Wastewater and Water  
Emission Activities and Sources**

**Version 1.1**

**July 2013**

**Developed by  
ICLEI – Local Governments for Sustainability USA**

For the latest version of this Protocol, and other tools and resources that can help you report on community GHG emissions, visit [www.icleiusa.org](http://www.icleiusa.org).

## Table of Contents

<b>Introduction.....</b>	<b>5</b>
<b>Table WW.1 Summary of Wastewater Treatment Process, Fugitive and Stationary Greenhouse Gas Emission Sources .....</b>	<b>15</b>
<b>Stationary Emissions.....</b>	<b>18</b>
<b>WW.1 Stationary Methane Emissions from Combustion of Digester Gas.....</b>	<b>18</b>
WW.1.a Method for CH <sub>4</sub> Emissions from the Combustion of Anaerobic Digester Gas when fraction of CH <sub>4</sub> is known .....	20
WW.1.b Method for CH <sub>4</sub> Emissions from the Combustion of Anaerobic Digester Gas when BTU content is known.....	21
WW.1.(alt) Alternative Method for Methane Emissions from Devices Designed to Combust Anaerobic Digester Gas if Only the Population is Known .....	23
<b>WW.2 Stationary Nitrous Oxide Emissions from Combustion of Digester Gas.....</b>	<b>25</b>
WW.2.a Method for N <sub>2</sub> O Emissions from the Combustion of Anaerobic Digester Gas when fraction of CH <sub>4</sub> is known .....	25
WW.2.b Method for N <sub>2</sub> O Emissions from the Combustion of Anaerobic Digester Gas when BTU content is known.....	27
WW.2.(alt) Method for N <sub>2</sub> O Emissions from Combustion when only Population Served by System is Known .....	28
<b>WW.3 Stationary CO<sub>2</sub> Emissions from Digester Gas Combustion .....</b>	<b>29</b>
<b>WW.4 Stationary Methane Emissions from Combustion of Biosolids and Sludges .....</b>	<b>31</b>
<b>WW.5 Stationary Nitrous Oxide Emissions from Combustion of Biosolids and Sludges .....</b>	<b>34</b>
<b>Process Emissions .....</b>	<b>36</b>
<b>WW.6 Process Methane Emissions from Wastewater Treatment Lagoons .....</b>	<b>36</b>
WW.6 Calculation if BOD <sub>5</sub> Load and Fraction of BOD <sub>5</sub> Removed in Primary Treatment (if applicable) are Known .....	37
WW.6 Alternate Method for Methane Emissions from Lagoons if Only the Population is Known... ..	38
<b>WW.7 Process Nitrous Oxide Emissions from Wastewater Treatment Plants with Nitrification or Denitrification.....</b>	<b>40</b>
<b>WW.8 Process Nitrous Oxide Emissions from Wastewater Treatment Plants without Nitrification or Denitrification.....</b>	<b>42</b>
<b>WW.9 Process Carbon Dioxide Emissions from the Use of Fossil-Fuel-Derived Methanol for Biological Nitrogen Removal .....</b>	<b>44</b>
<b>WW.10 Process Emissions from Cluster Package Systems.....</b>	<b>46</b>
<b>Fugitive Emissions.....</b>	<b>47</b>
<b>WW.11 Fugitive Methane Emissions from Septic Systems .....</b>	<b>47</b>
<b>WW.11 Fugitive Methane Emissions from Septic Systems if BOD<sub>5</sub> Load is Known .....</b>	<b>47</b>
WW.11.(alt) Alternative Method for Methane Emissions from Septic Systems if Only the Population is Known .....	48
<b>WW.12 Fugitive Nitrous Oxide Emissions from Effluent Discharge .....</b>	<b>53</b>
WW.12 Calculation if Average Total Nitrogen Discharged per Day (Total N-load) is Known.....	54
<b>WW.13 Attribution of Wastewater Emissions Outside of Operational Control .....</b>	<b>57</b>
<b>WW.13<sub>CH<sub>4</sub></sub> Attribution of Wastewater CH<sub>4</sub> Emissions .....</b>	<b>57</b>
WW.13 <sub>N<sub>2</sub>O</sub> Attribution of Wastewater N <sub>2</sub> O Emissions.....	58
<b>WW.14 Energy-related Emissions Associated with Water Delivery and Treatment .....</b>	<b>60</b>

Method WW.14 Calculation of Upstream Emissions Associated with Water Conveyance, Treatment and Delivery .....	63
<b>Table WW.14.2: Energy Intensities for Groundwater Extraction .....</b>	<b>72</b>
<b>Table WW.14.3: Energy Intensities for Water Conveyance .....</b>	<b>72</b>
<b>Table WW.14.4: Energy Intensities for Water Treatment.....</b>	<b>73</b>
<b>Table WW.14.5: Energy Intensities for Water Distribution.....</b>	<b>73</b>
<b>WW.15 Energy-related Emissions Associated with Wastewater Collection and Treatment .....</b>	<b>74</b>
<b>Example Calculations for Wastewater and Water Activities and Sources Emissions .....</b>	<b>90</b>
Box WW.1.a.....	90
Example Calculation of CH <sub>4</sub> Emissions from the Incomplete Combustion of Anaerobic Digester Gas with Fraction of CH <sub>4</sub> Known.....	90
Box WW.3.....	91
Example Calculation of Biogenic CO <sub>2</sub> Emissions from Digester Gas Combustion .....	91
Box WW.4.....	92
Example Calculation of CH <sub>4</sub> Emissions from the Combustion of WWTP Residuals on a Wet Weight Basis.....	92
Box WW.6(alt) .....	93
Example Calculation of CH <sub>4</sub> emissions from a Lagoon when only Population Served by Lagoon is Known.....	93
Box WW.8.....	94
Example Calculation of N <sub>2</sub> O Process Emissions from WWTP without Nitrification or Denitrification	94
Box WW.9.....	95
Example Calculation of CO <sub>2</sub> Emissions from Methanol Use .....	95
Box WW.11(alt) .....	96
Example Calculation of CH <sub>4</sub> emissions from a Septic System when only Population Served by System is Known.....	96
Box WW.12(alt) .....	97
Example Calculation of N <sub>2</sub> O Emissions from Effluent Conversion .....	97
Box WW.13 <sub>CH<sub>4</sub></sub> .....	98
Example Calculation of attributed CH <sub>4</sub> emissions .....	98
Box WW.14.....	99
Energy-related Emissions from Water Distribution and Treatment .....	99
Box WW.15.....	101
Energy-Related Emissions from Wastewater Collection and Treatment .....	101

## **Introduction**

### **Emissions Associated with Wastewater Treatment<sup>1</sup>**

Wastewater treatment can create a unique set of process, stationary, and fugitive greenhouse gas emissions. Methane (CH<sub>4</sub>) is produced when microorganisms degrade the soluble organic material in wastewater under anaerobic conditions. During collection and treatment, wastewater may be unintentionally or deliberately managed under anaerobic conditions, potentially releasing some uncaptured or uncombusted CH<sub>4</sub> into the environment.

Nitrous Oxide (N<sub>2</sub>O) is an intermediary product of both conventional treatment and specialized biologically mediated processes to remove excess nitrogen in wastewater. A fraction of the nitrogen discharged into natural waters may undergo similar processes and also produce N<sub>2</sub>O.

Carbon Dioxide (CO<sub>2</sub>) emissions from wastewater treatment are distinguished as either biogenic or fossil fuel based. Biogenic CO<sub>2</sub> is part of the short-term carbon cycle; these emissions may be optionally reported as a line item, but they should not be added into any inventory total. Fossil fuel based CO<sub>2</sub> emissions may come from the use of the use of fossil-based methanol in wastewater treatment plants (WWTP). Local governments are encouraged, but not required to track and report these emissions if they occur and if the local government has significant influence over them. Methane emissions from wastewater treatment are always anthropogenic.

Table WW.1 below summarizes the sources of stationary, fugitive and process greenhouse gas emissions outlined in this chapter. Paired with each source is a methodology explained later in this chapter. For any source, these methodologies may be substituted with on-site source tests using methodologies drawn from approved regulatory methods. On-site emissions results should be more representative of the emissions than the generic emission factors in this chapter and thus are preferred.

On the community level, power consumed to operate wastewater facilities located within the community will be bundled with energy consumption from the other sectors. Any electricity, natural gas or other fossil fuel consumed to power devices at these facilities should be included in the Industrial sector.

Every community generates wastewater, but not every community harbors or manages its own treatment system(s). Because every jurisdiction will have different kinds of wastewater treatment facilities, be very cautious in comparing emissions associated with wastewater treatment between communities. Regardless of community size, demographics or economic status, wastewater generation is unavoidable and these wastes must be treated before water is

---

<sup>1</sup> Currently, the understanding of greenhouse gases from all of these sectors is emerging. More resources may be added as our understanding improves.

returned to the environment. The wastewater treatment protects watersheds and prevents the spread of waterborne diseases. The practice of wastewater treatment thus provides a non-discretionary service to society.

Communities may achieve the goal of treating wastewater through either decentralized systems with treatment occurring at many locations; a main centralized facility at the terminus of an extensive sewage collection system; or a mix of the two. Communities may also enter into partnerships with other communities to treat their collective wastewater at a shared facility.

Communities adopting a decentralized approach have numerous systems scattered over a wide geographic area, and typically these disparate systems are not owned, operated or maintained by a local governing authority. Usually property owners are responsible for maintenance; however, a local enforcement agency may be responsible for inspecting and regulating these units.

Rural communities with dispersed population centers as well as many suburbs typically adopt a decentralized approach to wastewater treatment by using either household septic systems or cluster package systems. These smaller, remote and isolated systems rarely employ the complicated processes used at centralized facilities. Treatment and ultimate discharge is often very near the origins of the wastes treated.

A centralized system treats wastewaters collected in a network of sewers that lead to a larger, dedicated facility typically many miles from the origins of those wastes. Separately, many communities are members of a joint powers agreement with other communities or “special districts” that outsource the treatment responsibilities to one (or a few) of its members.

Urban communities with more densely packed population centers are more likely to use one or more centralized facilities for wastewater treatment. Most communities in the United States are served by collection systems that convey the sewage to such centralized facilities. When in doubt, assume a centralized aerobic treatment process is being used.

Centralized facilities typically employ an aerated treatment process to destroy soluble organics in wastewater. This aerated step may be configured to simply destroy only the organics in the sewage, or more advanced treatment may be included to remove other nutrients like nitrogen. The processes employed in these facilities are identical to processes that occur in nature and are managed to accelerate these natural processes within the controlled environment of the plant. These organics are derived from plant-based carbon hence CO<sub>2</sub> emissions from these processes, including the CO<sub>2</sub> generated from the combustion of digester gas, are considered a waste-derived biogenic source of CO<sub>2</sub> and are considered carbon-neutral for GHG accounting purposes.

Wastewater utilities may provide opportunities to offset GHG emissions from other sources. Utilities may generate renewable power from the biogas and/or biosolids produced from

wastewater treatment, reducing reliance on other nonrenewable fuel sources. Some wastewater treatment facilities may treat the water to advanced levels that may approach or even exceed drinking water standards. Such reclaimed waters can be used to displace imported water that may have a higher greenhouse gas footprint. Utilities may also have the opportunity to recover nutrients during wastewater treatment or to use biosolids as fertilizer, reducing greenhouse gas emissions from the production of synthetic fertilizers. Each wastewater utility is unique and will have its own site-specific opportunities and challenges related to offsetting GHG emissions.

### **Unit Operations Associated with Wastewater Treatment**

Wastewater treatment may employ one or more unit operations that may result in emissions of greenhouse gases. Although the number of unit processes is far greater than those presented here, this discussion is limited to those processes relevant to the protocols that have been developed thus far. These are:

**Septic Tanks:** Roughly one in five households in the United States depends on an individual septic (onsite) system to treat wastewater. Septic tanks typically contain underground stagnant and unaerated tank(s) where the treatment occurs by physical settling and biological activity. These systems typically do not have other wastewater unit operations associated with them. Emissions are mainly CH<sub>4</sub> with very little N<sub>2</sub>O generated.

**Lagoons:** Lagoons are shallow earthen basins varying in depth from 2 to 5 meters and yet may cover many acres. Some are operated with mechanical aeration while others are allowed to remain stagnant and may have periods of anaerobic activity where CH<sub>4</sub> may be produced. These basins use some combination of physical, chemical, and/or biological treatment processes that renders the wastewater more acceptable for discharge to the environment. They are not widely used because they tend to require large areas and supplemental treatment. These are typically centralized systems that may employ solids processing like anaerobic digestion.

**Conventional Treatment:** For purposes of this Protocol, conventional treatment refers to any centralized system other than a lagoon that degrades the dissolved organics in wastewater under aerobic conditions. When determining process and fugitive emissions, disparate systems such as attached growth (e.g. trickling filter) and activated sludge are treated the same. Currently, methods do not yet exist to distinguish between these (and other ) broad categories of BOD removal. These complicated systems may also employ anaerobic digestion for solids processing. When in doubt, calculate the emissions using formulas that apply to conventional activated sludge without nitrification or denitrification.

**Conventional Treatment with Nitrification or Denitrification:** These are centralized aerobic systems with additional treatment to either oxidize nitrogenous wastes to oxidized forms of nitrogen or the removal of nitrogen by a subsequent anoxic step that reduces the oxidized forms to elemental nitrogen gas. This latter conversion may be assisted by the oxidation of a supplemental form of carbon like methanol that results in the release of fossil-based carbon as CO<sub>2</sub>. These systems may employ digesters to manage the process solids. According to the United States Environmental Protection Agency (EPA) Clean Water Needs Survey, denitrification processes served only 2.4 million people in 2004, though this number is expected to increase.

**Digester Gas:** Organic solids from any of the above treatment processes may be further treated in enclosed, anaerobic tanks. Naturally occurring microorganisms (obligate anaerobes) degrade these organics in the absence of atmospheric oxygen to produce a gas consisting of roughly 65% CH<sub>4</sub> and 35% CO<sub>2</sub><sup>2</sup>. This gas can be captured and burned in devices to generate renewable, carbon-neutral energy. These tanks (digesters) are typically located at centralized facilities. Although septic tanks do not have digesters closely associated with them, settled material may periodically be siphoned out of a septic tank and hauled to a centralized facility where the solids could undergo anaerobic digestion.

**Combustion Devices:** These may include flares to combust excess anaerobic digester gas, boilers to generate steam to heat digesters or for facility space heating, internal combustion engines to generate either electric power or motive power to drive pumps and turbines for power and/or steam generation, or fuel cells. Although in practice the emissions from these devices will vary greatly, the accepted emission factors assume the same emissions profile regardless of the device used. Combustion devices may emit CH<sub>4</sub> from any uncombusted portion of the gas and N<sub>2</sub>O from the oxidation of nitrogen introduced in the combustion air. Since the gas generation processes are enclosed and must be kept free from exposure to atmospheric oxygen, the collection efficiencies are assumed to be 100% and the emission factors are based on emissions at the stack.

## Determining Contributions from Industrial Waste Discharges

*Box.1* is relevant for users determining whether a discharger is industrial and, therefore, whether a community should use the F<sub>ind-com</sub> factor of 1.25. F<sub>ind-com</sub> is meant to represent the level of industrial-commercial contributors to the collection system. Users have the option of using 1.0 for F<sub>ind-com</sub> if there is a demonstrated lack of significant industrial-commercial contributors. Otherwise, 1.25 should be used.

---

<sup>2</sup> See: Inventory of U.S. Greenhouse Gas Emissions and Sinks, <http://epa.gov/climatechange/emissions/downloads12/US-GHG-Inventory-2012-Chapter-8-Waste.pdf>



**Box. 1 Non-significant Categorical Industrial User (NSCIU)<sup>3</sup>**

An industrial user subject to categorical pretreatment standards under 40 CFR 403.6 and 40 CFR chapter I, subchapter N, that is exempt from the definition of SIU on a finding that the industrial user never discharges more than 100 gpd of total categorical wastewater (excluding sanitary, noncontact cooling and boiler blowdown wastewater, unless specifically included in the pretreatment standard). The industrial user must also meet the following conditions:

- The industrial user has consistently complied with all applicable categorical pretreatment standards and requirements.
- The industrial user annually submits the certification statement required in 40 CFR 403.12(q) together with any additional information necessary to support the certification statement.

The industrial user never discharges any untreated concentrated wastewater.

Source: 40 CFR 403.3(v)(2)

**Uncertainties**

According to the latest EPA national inventory of greenhouse gas emissions considerable uncertainty exists within any of the EPA/IPCC-based methodologies. EPA states that the estimates can under predict CH<sub>4</sub> emissions by 37% or over-predict by 47%. The range of uncertainty is even greater for N<sub>2</sub>O: the EPA-based methodologies could be under predicting by 76% or over predicting by 93%.<sup>4</sup> Emission estimates based on direct source measurements can possibly have higher accuracy and less uncertainty.

This extreme degree of uncertainty exists because these methodologies were originally developed for international countrywide inventories that were mainly population-based. By necessity, these methodologies were generalized “top-down” approaches that sought to provide emissions estimates for countries where detailed information would be impractical to obtain. Although these methodologies had the advantage of being relatively simple to calculate, the trade-off was a compromised level of accuracy. Nevertheless, the methodologies in this Appendix reflect the evolution of knowledge since the development of the LGOP.

In some cases, especially where the emissions are based on population and default inputs, communities should exercise caution in drawing conclusions or establishing policy. Moreover, communities should include a discussion of these uncertainties in their final analysis. As the methods evolve and these uncertainties are clarified ICLEI will update them.

<sup>3</sup> This reference is relevant for methods *WW.12.(alt)*, *WW.6.(alt)*, and *WW.8*.


<sup>4</sup> See: Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990–2009, EPA, 4/12/2011, Table 8-15, p. 8-16, <http://epa.gov/climatechange/emissions/downloads11/US-GHG-Inventory-2011-Chapter-8-Waste.pdf>

## **Overall Strategy for Determining Wastewater Emissions**


Please refer to Chart WW.1 to determine your initial steps in calculating your greenhouse gas emissions from wastewater treatment processes. Each decision result in that flow chart guides the user to methods needed to calculate emissions in Figures WW.2 through WW.4. In some cases, a community may employ a mix of strategies to meet their wastewater needs, so emissions may be calculated using more than one method. These results should be in proportion to the percentage of the population served by that process.

Flow charts for calculating electricity demand for water and wastewater management are found with methods WW.14 and WW.15 respectively.


**CHART WW.1: Decision Tree for Reporting Emissions from Wastewater Treatment Technologies within your Community**




**CHART WW.2: Decision Tree for Reporting Emissions from Community Septic Tanks**



**CHART WW.3: Decision Tree for Reporting Emissions from Wastewater Treatment Lagoons within your Community**



**CHART WW.4: Decision Tree for Reporting Emissions from Conventional Aerobic Wastewater Treatment Systems**



**Table WW.1 Summary of Wastewater Treatment Process, Fugitive and Stationary Greenhouse Gas Emission Sources**

<b>GHG Type</b>	<b>GHG Source</b>	<b>Data Required</b>	<b>Available Methodologies</b>
Stationary CH <sub>4</sub> emissions	Combustion of digester gas at a centralized WWTP with anaerobic digestion of biosolids – process data known	- Digester gas (ft <sup>3</sup> /day) - Fraction of CH <sub>4</sub> in biogas	WW.1.a
		OR	
		- Digester gas (ft <sup>3</sup> /day) - BTU content of biogas	WW.1.b
Stationary CH <sub>4</sub> emissions	Combustion of digester gas at a centralized WWTP with anaerobic digestion of biosolids – population served basis	- Population served	WW.1.(alt)
Stationary N <sub>2</sub> O emissions	Combustion of digester gas at a centralized WWTP with anaerobic digestion of biosolids – process data known	- Digester gas (ft <sup>3</sup> /day) - Fraction of CH <sub>4</sub> in biogas	WW.2.a
		OR	
		- Digester gas (ft <sup>3</sup> /day) - BTU content of biogas	WW.2.b
Stationary N <sub>2</sub> O emissions	Combustion of digester gas at a centralized WWTP with anaerobic digestion of biosolids – population served basis	- Population served	WW.2.(alt)
Stationary CO <sub>2</sub> Emissions (optional)	Combustion of digester gas at a centralized WWTP with anaerobic digestion of biosolids – process data known	- Digester gas (ft <sup>3</sup> /day) - BTU content of biogas	WW.3
Stationary CH <sub>4</sub> emissions	Emissions from residuals combustion	- Mass of material sent to combustion device	WW.4
Stationary N <sub>2</sub> O emissions	Emissions from residuals combustion	- Mass of material sent to combustion device	WW.5
Process CH <sub>4</sub> emissions	Anaerobic or Facultative Lagoons	- Biochemical Oxygen Demand (BOD <sub>5</sub> ) load (kilograms (kg) BOD <sub>5</sub> /day) - Fraction of overall BOD <sub>5</sub> removal performance	WW.6
		OR	
		- Population served	WW.6 (alt)

<b>GHG Type</b>	<b>GHG Source</b>	<b>Data Required</b>	<b>Available Methodologies</b>
Process N <sub>2</sub> O emissions	Centralized WWTP with nitrification/denitrification or aeration basin	- Population served	WW.7
Process N <sub>2</sub> O emissions	Centralized WWTP without nitrification/denitrification or aeration basin	- Population served	WW.8
Process CO <sub>2</sub> emissions	CO <sub>2</sub> emissions from the use of fossil-fuel-derived methanol for biological nitrogen removal in a WWTP	- Methanol load (metric tons (mt) CH <sub>3</sub> OH/day) - Treatment type (Raw solids, anaerobic digestion, or solid combustion)	WW.9
Process N <sub>2</sub> O emissions	Cluster Package System	- Population served	WW.10
Fugitive CH <sub>4</sub> emissions	Septic Systems	- BOD <sub>5</sub> load (kg BOD <sub>5</sub> /day)	WW.11
		OR	
		- Population Served	WW.11(alt)
Fugitive N <sub>2</sub> O emissions	Effluent discharge to receiving aquatic environments	- N Load (kg N/day)	WW.12
		OR	
		- Population Served	WW.12(alt)
Attributed CH <sub>4</sub> Emissions	Process emissions from cluster package systems	- Population of community served by given facility - Total population the facility serves - Total CH <sub>4</sub> emissions from facility (mtCO <sub>2</sub> e)	WW.13 <sub>CH<sub>4</sub></sub>
Attributed N <sub>2</sub> O Emissions	Attributed emissions	- Population of community served by given facility - Total population the facility serves - Total N <sub>2</sub> O emissions from facility (mtCO <sub>2</sub> e)	WW.13 <sub>N<sub>2</sub>O</sub>



GHG Type	GHG Source	Data Required	Available Methodologies
CO <sub>2</sub> , CH <sub>4</sub> , and N <sub>2</sub> O from use of electricity or fuels	Lifecycle Emissions Associated with Water Acquisition, Distribution and Treatment	<ul style="list-style-type: none"> <li>- Energy consumption in each process in the water supply and wastewater treatment system, applicable to the community (locally derived value for energy consumer/unit water consumed)</li> </ul> <p style="text-align: center;">OR</p> <ul style="list-style-type: none"> <li>- National average energy consumption/unit of water</li> <li>- Annual volume of water passing through each process in the water supply and wastewater treatment system</li> </ul>	WW.14
CO <sub>2</sub> , CH <sub>4</sub> , and N <sub>2</sub> O from use of electricity or fuels	Lifecycle Emissions Associated with Wastewater Acquisition, Distribution and Treatment	<ul style="list-style-type: none"> <li>- Energy consumption in each process in the water supply and wastewater treatment system, applicable to the community (locally derived value for energy consumer/unit water consumed)</li> </ul> <p style="text-align: center;">OR</p> <ul style="list-style-type: none"> <li>- National average energy consumption/unit of water</li> <li>- Population</li> <li>- Per Capita wastewater generation</li> <li>- Percentage of population serviced by centralized wastewater treatment systems</li> <li>- Percentage of population serviced by each treatment modality</li> </ul>	WW.15

## Stationary Emissions

### WW.1 Stationary Methane Emissions from Combustion of Digester Gas

#### Introduction

This section provides equations for calculating the stationary CH<sub>4</sub> emissions from devices designed to combust gas produced by anaerobic digesters based on site-specific data or the population served by a centralized WWTP that uses anaerobic digesters. Each method provides a description and appropriate default values (where applicable) for each term in the following equations. As mentioned in the Introduction to this chapter, the biogenic CO<sub>2</sub> emissions from the combustion of digester gas are part of the short-term carbon cycle and thus are considered Scope 3 emissions, and are optional to report.

Anaerobic digesters are often operated to treat the excess sludges produced by the wastewater treatment process, producing a final product called biosolids. The anaerobic digestion of sludges and other organic wastes also produces CH<sub>4</sub>. This CH<sub>4</sub> is often re-used as a carbon-neutral fuel to produce electricity or heat. Due to small inefficiencies in any combustion process, incomplete combustion of digester gas is a source of stationary CH<sub>4</sub> emissions. Additionally, the combustion of this fuel in air will result in the formation of not only the criteria pollutant oxides of nitrogen (NO<sub>x</sub>), but also the greenhouse gas, N<sub>2</sub>O. Many very small plants in the US use aerobic digestion and hence there is no digester gas produced. Also, many medium to large publicly owned treatment works on the east coast use lime stabilization and don't digest at all.

Because combustion devices are sized to match the gas production potential of the digesters, these devices are typically not found in smaller centralized WWTPs, nor in septic systems or package treatment plants. For these smaller systems, solids (septic tank residuals, primary settling sludges and secondary treatment waste activated sludges) may be removed and transported to a centralized facility where they are combined with the other organics, and ultimately digested at larger facilities. Currently a standardized methodology does not exist to estimate the sludge volumes removed from small systems and treated at a remote facility. Therefore, the equations in this section should only be applied to centralized treatment facilities that support anaerobic digestion.

Some centralized facilities may use aerobic digestion instead, or may simply dewater their sludges for alternative treatment (e.g., lime stabilization, composting, incineration), bypassing anaerobic digestion altogether. These facilities would also not use these formulas because these alternatives would not produce digester gas. Although these practices generate GHG emissions, current standardized methodologies to calculate these emissions do not exist.

To calculate the stationary CH<sub>4</sub> emissions from devices designed to combust digester gas, please follow *Method WW.1.a* or *Method WW.1.b* if process flow information is available.

Otherwise, follow *Method WW.1.(alt)* to estimate the emissions based on population served by the centralized facility that uses anaerobic digestion.

Please note that if you are generating power or heat at your wastewater treatment facility and the electricity and/or heat are consumed entirely within the facility, you should report the combustion emissions from generating that power in Appendix F: Wastewater Emission Activities and Sources, not in Appendix C: the Built Environment Emissions Activities and Sources. If you generate power that is distributed outside your facility, report those emissions in Appendix C: the Built Environment Emissions Activities and Sources.

Although this Protocol cannot be used to generate reports required under the EPA or the California Air Resources Board mandatory reporting rules, facilities that are subject to those requirements can use *Method WW.1.a* OR *WW.1.b* to avoid having to prepare multiple reports with differing requirements. Facilities not subject to mandatory reporting rules that have site-specific digester gas heat or CH<sub>4</sub> content information are also welcome to use these methods.

**Finally, site-specific source test information using methods developed or approved by regulatory agencies is often better than any of these methods.**

**WW.1 Data Needs**

Below are the data inputs a user will need to collect in order to estimate the stationary CH<sub>4</sub> emitted by a digester gas combustion device:

If Process Information is Available:	Measured standard cubic feet of digester gas produced per day (std ft <sup>3</sup> /day) ( <i>Methods WW.1 a &amp;b</i> )
	Fraction of CH <sub>4</sub> in biogas ( <i>Method WW.1.a</i> ) OR BTU content ( <i>Method WW.1.b</i> )
If Only Population Served is Available:	Population ( <i>Method WW.1.(alt)</i> )

## **WW.1.a Method for CH<sub>4</sub> Emissions from the Combustion of Anaerobic Digester Gas when fraction of CH<sub>4</sub> is known**

### **WW.1.a Data Needs**

- Measured standard cubic feet of digester gas produced per day (std ft<sup>3</sup>/day)
- Fraction of CH<sub>4</sub> in biogas

### **WW.1.a Calculation Method**

The method presented consists of the following three steps:

**Step 1:** Determine the amount of volume of digester gas produced per day. This is the total volume of digester gas produced per day by the digesters at the facility.

**Step 2:** Determine the fraction of CH<sub>4</sub> in that gas. Since not all the gas produced by the digester is CH<sub>4</sub>, focus only on the CH<sub>4</sub>.

**Step 3:** Enter above variables into *Equation WW.1.a*. Use the default values provided in the equation for kg CH<sub>4</sub> per million BTU combusted, GWP, and unit conversions. Enter these values along with the obtained values for volume of digester gas and fCH<sub>4</sub> into *Equation WW.1.a* to calculate stationary CH<sub>4</sub> emissions from the incomplete combustion of digester gas in mtCO<sub>2</sub>e. Note: that although some facilities do not burn all the gas in a boiler, but flare some portion of it, there is currently no approved methods that distinguish between fuel burning devices. Moreover, the overall combustion inefficiency of different devices (boilers, engines, combustion turbines, conventional flares, and low-emissions/low-NO<sub>x</sub> flares) can vary widely.

<b>Equation WW.1.a Emissions from Devices Designed to Combust Digester Gas, with CH<sub>4</sub> Content Known</b>		
Annual CH <sub>4</sub> emissions = (Digester Gas × f <sub>CH<sub>4</sub></sub> × BTU <sub>CH<sub>4</sub></sub> × 10 <sup>-6</sup> × EF <sub>CH<sub>4</sub></sub> × 365.25 × 10 <sup>-3</sup> ) × GWP		
Where:		
Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by incomplete combustion (mtCO <sub>2</sub> e)	Result
Digester gas	= Standard cubic feet of digester gas produced per day (std ft <sup>3</sup> /day)	User Input
f <sub>CH<sub>4</sub></sub>	= Fraction of CH <sub>4</sub> in gas	User Input
BTU <sub>CH<sub>4</sub></sub>	= Default BTU content of CH <sub>4</sub> , higher heating value (BTU/ft <sup>3</sup> )	1028 (nation-wide average)
10 <sup>-6</sup>	= Conversion from BTU to 1 MMBTU	10 <sup>-6</sup>
EF <sub>CH<sub>4</sub></sub>	= CH <sub>4</sub> emission factor (kg CH <sub>4</sub> /MMBTU)	3.2 × 10 <sup>-3</sup> kg CH <sub>4</sub> per MMBTU
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>5</sup>
<b>Equation WW.1.a Emissions from Devices Designed to Combust Digester Gas, with CH<sub>4</sub> Content Known</b>		
Source: In 40 CFR Part 98, Mandatory Reporting of Greenhouse Gases; Final Rule, Table C-2, page 79154 of the Federal Register / Vol. 75, No. 242 / Friday, December 17, 2010 / Rules and Regulations, is referenced an emission factor for digester gas combustion: 3.2 × 10 <sup>-3</sup> kg CH <sub>4</sub> per million BTU. See: <a href="http://edocket.access.gpo.gov/2010/pdf/2010-30286.pdf">http://edocket.access.gpo.gov/2010/pdf/2010-30286.pdf</a>		

### **WW.1.b Method for CH<sub>4</sub> Emissions from the Combustion of Anaerobic Digester Gas when BTU content is known**

#### **WW.1.b Data Needs**

- Measured standard cubic feet of digester gas produced per day (std ft<sup>3</sup>/day)
- BTU content

#### **WW.1.b Calculation Method**

The method presented consists of the following three steps:

**Step 1:** Determine the volume of digester gas produced per day.

<sup>5</sup> See Appendix GWP for value.

**Step 2:** Determine the BTU content of that gas. The BTU content is de-rated from natural gas because not all the gas is CH<sub>4</sub> and is obtained from either on-line analyzers or routine laboratory analysis.

**Step 3:** Enter above variables into *Equation WW.1.b*. Use the default values for kg CH<sub>4</sub> per million BTU combusted, GWP, and unit conversions. Enter these values along with the obtained values for volume of digester gas and BTU into *Equation WW.1.b* to calculate stationary CH<sub>4</sub> emissions from devices designed to combust digester gas in mtCO<sub>2</sub>e

**Although CH<sub>4</sub> constitutes the vast majority of combustible materials in digester gas, there are many other trace hydrocarbons, which may affect the BTU content of that fuel. Therefore, if the BTU content is known, more accurate results will be obtained even if the percent CH<sub>4</sub> is known as well. In that case, use *Equation WW.1.b* below:**

<b>Equation WW.1.b Emissions from the Incomplete Combustion of Anaerobic Digester Gas with BTU Content Known</b>		
<i>Annual CH<sub>4</sub> emissions = (Digester Gas × BTU<sub>digester gas</sub> × 10<sup>-6</sup> × EF<sub>CH4</sub> × 365.25 × 10<sup>-3</sup>) × GWP</i>		
Where:		
Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by incomplete combustion (mtCO <sub>2</sub> e)	Result
Digester gas	= Standard cubic feet of digester gas produced per day (std ft <sup>3</sup> /day)	User Input
BTU <sub>digester gas</sub>	= BTU content of digester gas, higher heating value (BTU/ft <sup>3</sup> )	User Input
10 <sup>-6</sup>	= Conversion from BTU to 1 MMBTU	10 <sup>-6</sup>
EF <sub>CH4</sub>	= CH <sub>4</sub> emission factor (kg CH <sub>4</sub> /MMBTU)	3.2 X 10 <sup>-3</sup> kg CH <sub>4</sub> per MMBTU
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH4</sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>6</sup>
Source: In 40 CFR Part 98, Mandatory Reporting of Greenhouse Gases; Final Rule, Table C-2, page 79154 of the Federal Register / Vol. 75, No. 242 / Friday, December 17, 2010 / Rules and Regulations, is referenced an emission factor for digester gas combustion: 3.2 X 10 <sup>-3</sup> kg CH <sub>4</sub> per million BTU. See: <a href="http://edocket.access.gpo.gov/2010/pdf/2010-30286.pdf">http://edocket.access.gpo.gov/2010/pdf/2010-30286.pdf</a>		

<sup>6</sup> See Appendix GWP for value.

## **WW.1.(alt) Alternative Method for Methane Emissions from Devices Designed to Combust Anaerobic Digester Gas if Only the Population is Known**

If site-specific data on volume of digester biogas produced and the fraction of CH<sub>4</sub> in the biogas or the BTU content are not available, the alternative methodology should be employed. The only data collection required by this methodology is the population served by the WWTP with anaerobic digesters.

### **WW.1.(alt) Data Needs**

- Population served by the facility (P)

### **WW.1.(alt) Calculation Method**

The method presented consists of the following two steps:

**Step 1:** Determine the population served by the facility with digesters.

**Step 2:** Enter above variables into *Equation WW.1.(alt)*. Use the provided default values for digester gas,  $f_{CH_4}$ ,  $BTU_{CH_4}$ ,  $EF_{CH_4}$ , GWP, and unit conversions. Enter these values into *Equation WW.1.(alt)* to calculate CH<sub>4</sub> emissions from devices designed to combust digester gas in mtCO<sub>2</sub>e.

**Equation WW.1. (alt) Emissions from Devices Designed to Combust Anaerobic Digester Gas**

$$\text{Annual CH}_4 \text{ emissions} = (P \times \text{Digester Gas} \times f_{\text{CH}_4} \times \text{BTU}_{\text{CH}_4} \times 10^{-6} \times \text{EF}_{\text{CH}_4} \times 365.25 \times 10^{-3}) \times \text{GWP}$$

Where:

Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by devices designed to combust digester gas (mtCO <sub>2</sub> e)	Result
P	= Population served by the WWTP with anaerobic digesters	User input
Digester gas	= Standard cubic feet of digester gas produced per person per day (std ft <sup>3</sup> /person/day)	1.0
f <sub>CH<sub>4</sub></sub>	= Fraction of CH <sub>4</sub> in gas	0.65
BTU <sub>CH<sub>4</sub></sub>	= Default BTU content of CH <sub>4</sub> , higher heating value (BTU/ft <sup>3</sup> )	1028
10 <sup>-6</sup>	= Conversion from BTU to 1 MMBTU	10 <sup>-6</sup>
EF <sub>CH<sub>4</sub></sub>	= CH <sub>4</sub> emission factor (kg CH <sub>4</sub> /MMBTU)	3.2 X 10 <sup>-3</sup> kg CH <sub>4</sub> per MMBTU
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>7</sup>

Source: As listed in LGO Equation 10.2 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2007, Chapter 8, 8-7 (2009) and 40 CFR Part 98, Mandatory Reporting of Greenhouse Gases; Final Rule, Table C-2, page 79154 of the Federal Register / Vol. 75, No. 242 / Friday, December 17, 2010 / Rules and Regulations, is referenced an emission factor for digester gas combustion: 3.2 X 10<sup>-3</sup> kg CH<sub>4</sub> per million BTU. See: <http://edocket.access.gpo.gov/2010/pdf/2010-30286.pdf>

<sup>7</sup> See Appendix GWP for value.



## WW.2 Stationary Nitrous Oxide Emissions from Combustion of Digester Gas

### Introduction

N<sub>2</sub>O is not generated in significant amounts in anaerobic digesters. However, other nitrogen containing compounds in the gas or nitrogen in the combustion air may be converted in small amounts to N<sub>2</sub>O during combustion. Please note that N<sub>2</sub>O is NOT considered the same as NO<sub>x</sub>, which is a criteria pollutant<sup>8</sup>, so a facility should not use NO<sub>x</sub> information to estimate their N<sub>2</sub>O emissions.

For N<sub>2</sub>O emissions from the combustion of digester gas, use **the same formulas** as for CH<sub>4</sub> (either *WW.1.a*, *WW.1.b*, or *WW.1.(alt)*)**except:**

- Replace the CH<sub>4</sub> emission factor, EF<sub>CH<sub>4</sub></sub> (3.2 X 10<sup>-3</sup> kg CH<sub>4</sub> per MMBTU) with the N<sub>2</sub>O emission factor, EF<sub>N<sub>2</sub>O</sub> (6.3 X 10<sup>-4</sup> kg N<sub>2</sub>O per MMBTU)  
AND
- Replace the CH<sub>4</sub> GWP (21) with the N<sub>2</sub>O GWP (310).

Examples are provided below.

Please note that if you are generating power or heat at your wastewater treatment facility and the electricity and/or heat are consumed entirely within the facility, you should report the combustion emissions from generating that power in Appendix F: Wastewater and Water Emission Activities and Sources, not in Appendix C: the Built Environment Emissions Activities and Sources. If you generate power that is distributed outside your facility, report those emissions in Appendix C: the Built Environment Emissions Activities and Sources.

Although this Protocol cannot be used to generate reports required under the EPA or the California Air Resources Board mandatory reporting rules, facilities that are subject to those requirements can use *Method WW.2.a* OR *WW.2.b* for consistency's sake. Facilities not subject to mandatory reporting rules that have site-specific gas heat or CH<sub>4</sub> content information are also welcome to use these methods.

Finally, site-specific source test information using methods developed or approved by regulatory agencies is often better than any of these methods.

### **WW.2.a Method for N<sub>2</sub>O Emissions from the Combustion of Anaerobic Digester Gas when fraction of CH<sub>4</sub> is known**

*Box WW.2.a* below gives an example of how to calculate the N<sub>2</sub>O emissions from the combustion of digester gas using the methodology consistent with the EPA and California Air

<sup>8</sup> The South Coast Air Quality Management District in their Rule 1110.2 defines NO<sub>x</sub> as "OXIDES OF NITROGEN (NO<sub>x</sub>) means nitric oxide and nitrogen dioxide." See: <http://www.aqmd.gov/rules/reg/reg11/r1110-2.pdf>, §(c)(13).

Resources Board mandatory reporting rules if the fraction of CH<sub>4</sub> in the digester gas is known, using *Method WW1.a*.

<b>Box WW.2.a</b>		<b>Example Calculation of N<sub>2</sub>O Emissions from the Combustion of Anaerobic Digester Gas when fraction of CH<sub>4</sub> is known</b>	
A wastewater facility generates 1,000,000 ft <sup>3</sup> per day of digester gas containing 65% CH <sub>4</sub> . The BTU content of the digester gas is not available. Based on this scenario the N <sub>2</sub> O emissions from the combustion of digester biogas can be calculated as follows			
Description		Value	
N <sub>2</sub> O emissions	= Total N <sub>2</sub> O emitted by combustion (mtCO <sub>2</sub> e)	Result	
Digester gas	= Measured standard cubic feet of digester gas produced per day (std ft <sup>3</sup> / day)	1,000,000	
fCH <sub>4</sub>	= Fraction of CH <sub>4</sub> in biogas	0.65	
BTU <sub>CH4</sub>	= Default BTU content of CH <sub>4</sub> , higher heating value (BTU/ft <sup>3</sup> )	1028	
10 <sup>-6</sup>	= Conversion from BTU to 1 MMBTU	10 <sup>-6</sup>	
EF <sub>N2O</sub>	= N <sub>2</sub> O emission factor (kg N <sub>2</sub> O/MMBTU)	6.3 X 10 <sup>-4</sup> kg N <sub>2</sub> O per MMBTU	
365.25	= Conversion factor (day/year)	365.25	
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>	
GWP <sub>N2O</sub>	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>9</sup>	
Sample Calculation:			
$\text{Annual N}_2\text{O emissions} = (1,000,000 \times 0.65 \times 1028 \times 10^{-6} \times (6.3 \times 10^{-4}) \times 365.25 \times 10^{-3}) \times 310$ $= 47.7 \text{ mtCO}_2\text{e}$			

<sup>9</sup> See Appendix GWP for value.

**WW.2.b Method for N<sub>2</sub>O Emissions from the Combustion of Anaerobic Digester Gas when BTU content is known**

Box WW.2.b below gives an example of how to calculate the N<sub>2</sub>O emissions from the combustion of digester gas using the methodology consistent with the EPA and California Air Resources Board mandatory reporting rules if the BTU content is known, using *Method WW.1.b*.

<b>Box WW.2.b Example Calculation of N<sub>2</sub>O Emissions from the Combustion of Anaerobic Digester Gas when BTU content is known</b>		
A wastewater facility generates 1,000,000 ft <sup>3</sup> per day of digester gas containing 60% CH <sub>4</sub> and has a BTU content of 622 BTU/ft <sup>3</sup> . Based on this scenario the N <sub>2</sub> O emissions from the combustion of digester biogas can be calculated as follows using <i>Equation WW.2.b</i>		
Description		Value
N <sub>2</sub> O emissions	= Total N <sub>2</sub> O emitted by combustion (mtCO <sub>2</sub> e)	Result
Digester gas	= Measured standard cubic feet of digester gas produced per day (std ft <sup>3</sup> / day)	1,000,000
BTU <sub>digester gas</sub>	= BTU content of digester gas, higher heating value (BTU/ft <sup>3</sup> )	622
10 <sup>-6</sup>	= Conversion from BTU to 1 MMBTU	10 <sup>-6</sup>
EF <sub>N<sub>2</sub>O</sub>	= N <sub>2</sub> O emission factor (kg N <sub>2</sub> O/MMBTU)	6.3 X 10 <sup>-4</sup> kg N <sub>2</sub> O per MMBTU
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
Description		Value
GWP <sub>N<sub>2</sub>O</sub>	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>10</sup>
Sample Calculation: $\text{Annual N}_2\text{O emissions} = (1,000,000 \times 622 \times 10^{-6} \times (6.3 \times 10^{-4}) \times 365.25 \times 10^{-3}) \times 310$ $= 44.4 \text{ mtCO}_2\text{e}$		

<sup>10</sup> See Appendix GWP for value.

**WW.2.(alt) Method for N<sub>2</sub>O Emissions from Combustion when only Population Served by System is Known**

Box WW.2.(alt) below gives an example of how to calculate the N<sub>2</sub>O emission from the incomplete combustion of digester gas when the only data obtainable is population served by the facility supporting digestion, using Method WW.1.(alt).

<b>Box WW.2.(alt) Example Calculation of N<sub>2</sub>O Emissions from Combustion when only Population Served by System is Known</b>		
A centralized wastewater facility serves a city with a population of 100,000 people. No other data is available. Based on this scenario the N <sub>2</sub> O emissions from the combustion of digester biogas can be calculated as follows		
Description		Value
N <sub>2</sub> O emissions	= Total N <sub>2</sub> O emitted by combustion (mtCO <sub>2</sub> e)	Result
P	= Population served by anaerobic digester	100,000
Digester gas	= Measured standard cubic feet of digester gas produced per person per day (std ft <sup>3</sup> /person/day)	1.0
fCH <sub>4</sub>	= Fraction of CH <sub>4</sub> in biogas	0.65
BTU <sub>CH4</sub>	= Default BTU content of CH <sub>4</sub> , higher heating value (BTU/ft <sup>3</sup> )	1028
10 <sup>-6</sup>	= Conversion from BTU to 1 MMBTU	10 <sup>-6</sup>
EF <sub>N2O</sub>	= N <sub>2</sub> O emission factor (kg N <sub>2</sub> O/MMBTU)	6.3 X 10 <sup>-4</sup> kg N <sub>2</sub> O per MMBTU
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>N<sub>2</sub>O</sub>	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>11</sup>
Sample Calculation: $\text{Annual N}_2\text{O emissions} = (100,000 \times 1 \times 0.65 \times 1028 \times 10^{-6} \times (6.3 \times 10^{-4}) \times 365.25 \times 10^{-3}) \times 310$ $= 4.8 \text{ mtCO}_2\text{e}$		

<sup>11</sup> See Appendix GWP for value.

## WW.3 Stationary CO<sub>2</sub> Emissions from Digester Gas Combustion

### Introduction

This section provides equations for calculating biogenic CO<sub>2</sub> emissions from the combustion of carbon-neutral gas produced by anaerobic digesters. The method provides a description and appropriate default values (where applicable) for each term in the following equation. As explained in the Introduction to this chapter, CO<sub>2</sub> emissions from this source are part of the short-term carbon cycle and thus are considered Scope 3 emissions from renewable fuels meant to displace fossil-fuel use. The methodology presented below is an optional method to track biogenic CO<sub>2</sub>.

Please note that if you are generating power or heat at your wastewater treatment facility and the electricity and/or heat are consumed entirely within the facility, you should report the combustion emissions from generating that power in Appendix F: Wastewater and Water Emission Activities and Sources, not in Appendix C: the Built Environment Emissions Activities and Sources. If you generate power that is distributed outside your facility, report those emissions in Appendix C: the Built Environment Emissions Activities and Sources.

### WW.3 Data Needs

- Cubic feet of digester gas produced per day (digester gas), standard cubic feet/day
- BTU content of digester (BTU<sub>CO2</sub>), MMBtu/scf (default available if there is no site-specific data)

### WW.3 Method Calculation

The method presented consists of the following three steps:

**Step 1:** Determine the amount of volume of digester gas produced per day.

**Step 2:** Determine the BTU content of the digester gas in MMBTU/scf. If no data is available on the BTU content of the gas then the default value of 0.00084 MMBTU/scf can be used. Please note this value is MUCH higher than the typical BTU content of digester gas. Using this default value will significantly elevate the emissions estimate.

**Step 3:** Enter above variables into *Equation WW.3* below. Use the default values for the emissions factor and the conversion factors provided to determine the annual CO<sub>2</sub> emissions from digester gas combustion.

**Equation WW.3 CO<sub>2</sub> Emissions from Digester gas Combustion**

$$\text{Annual CO}_2 \text{ emissions} = \text{Digester gas} * \text{BTU}_{\text{CO}_2} * \text{EF}_{\text{CO}_2} * 365.25 * 10^{-3}$$

Where:

Description		Value
CO <sub>2</sub> emissions	= Total annual biogenic CO <sub>2</sub> emitted by combustion of biogas (mtCO <sub>2</sub> e)	Result
Digester gas	= Standard cubic feet of digester gas produced per day (std ft <sup>3</sup> /day)	User input
BTU <sub>CO<sub>2</sub></sub>	= BTU content of biogas (MMBTU/scf)	User input or 0.000841
EF <sub>CO<sub>2</sub></sub>	= Emission factor for CO <sub>2</sub> (kg CO <sub>2</sub> / MMBTU)	52.07
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion factor kg to mt	10 <sup>-3</sup>

Source: Table G.2 of the Local Government Operations Protocol version 1.1 May, 2010

## WW.4 Stationary Methane Emissions from Combustion of Biosolids and Sludges

### Introduction

This section provides equations for calculating the stationary CH<sub>4</sub> emissions from the combustion of biosolids and sludges produced by treatment plant processes based on site-specific data. There is no alternative method based solely on population. The method provides a description and appropriate default values (where applicable) for each term in the following equation.

The CO<sub>2</sub> emissions from this combustion of biosolids and sludges are part of the short-term carbon cycle. The methodologies for the CO<sub>2</sub> emissions from combustion of biosolids and sludges are contained in the Power Generation chapter of this Protocol, and should be used when these fuels are used to generate power for export. When these fuels are burned to meet internal facility power needs or for purposes other than exporting power, the methods in this section should be used.

Sludges generated by processes within the treatment plant are concentrated and collected in settling basins. Solids from primary sedimentation tanks derive from the settled organic material collected by those tanks. Similarly, secondary treatment sludges derive from the settled biomass generated in the biological treatment step and settled out in the secondary clarifiers. Advanced wastewater treatment methods may generate organic sludges as well.

Anaerobic digesters are often operated to stabilize the sludges produced by the wastewater treatment process, producing a final product called biosolids. The anaerobic digestion of sludges and other organic wastes produces biogas-containing CH<sub>4</sub>. Although significant amounts of CH<sub>4</sub> are produced, the biosolids leaving the digester will contain organics that may be combusted. The organics in raw (un-digested) sludges may also be combusted. Dewatering of these residuals is required before any combustion can occur.

Because combustion devices are sized to match the solids production potential of the treatment plant, these devices are typically not found in smaller centralized WWTPs, or in septic systems or package treatment plants. For these smaller systems, solids (primary settling sludges and secondary treatment waste activated sludges) are occasionally removed and transported to a centralized facility. Combined with the other organics, the sludges are ultimately digested at those larger facilities. Currently a standardized methodology to estimate the sludge volumes removed from small systems and treated at a remote facility does not exist. Therefore, the equations in this section should only be applied to centralized treatment facilities that support solids treatment.

To calculate the stationary CH<sub>4</sub> emissions from the combustion of treatment plant residuals please follow *Method WW.4 Stationary Methane Emissions from Combustion of Sludges and Biosolids* if process information is available. If no process information is available, it is not possible to calculate emissions from this source. Also, this factor is based on a wet weight basis.

If the dry weight is reported and the percent by weight of water is known after the dewatering step, the user should back-calculate the wet weight and then perform the calculations.

Larger municipalities often employ a portfolio of methods to affect final disposal of their WWTP residuals. Incineration may be one of several options used by a municipality to diversify their options. Therefore, it is not always the case that 100% of the residuals will be incinerated. The user of this protocol should verify that the mass of material entered into the equation accurately reflects the mass incinerated and not blindly assume all the facility's residuals are processed that way.

Please note that if you are generating power or heat at your wastewater treatment facility and the electricity and/or heat are consumed entirely within the facility, you should report the combustion emissions from generating that power in Appendix F: Wastewater Emission Activities and Sources, not in Appendix C: the Built Environment Emissions Activities and Sources. If you generate power that is distributed outside your facility, report those emissions in Appendix C: the Built Environment Emissions Activities and Sources.

Finally, site-specific source test information using methods developed or approved by regulatory agencies is often better than any of these methods.

#### **WW.4 Data Needs**

- Measured mass of biosolids or sludges sent to incineration, wet weight (mt/day)

#### **WW.4 Calculation Based on the Wet Weight of Material Combusted**

The method presented consists of the following two steps:

**Step 1:** Determine the mass of residuals combusted per day. This is the total mass in kg of the wet weight of sludges or biosolids combusted.

**Step 2:** Enter above variables into *Equation WW.4*. Use the default emission factor for grams CH<sub>4</sub> per mt wet weight material combusted, GWP, and unit conversions. Enter these values into *Equation WW.4* to calculate stationary CH<sub>4</sub> emissions from the incomplete combustion of digester gas in mtCO<sub>2</sub>e.



**Equation WW.4 CH<sub>4</sub> Emissions from the Combustion of Wastewater Treatment Plant Residuals on a Wet Weight Basis**

$$\text{Annual CH}_4 \text{ emissions} = (\text{Wet Weight} \times EF_{\text{CH}_4} \times 365.25 \times 10^{-6}) \times \text{GWP}$$

Where:

Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by incomplete combustion (mtCO <sub>2</sub> e)	Result
Wet Weight	= Wet weight of sludges or biosolids incinerated (mt/day)	User Input
EF <sub>CH<sub>4</sub></sub>	= CH <sub>4</sub> emission factor (g CH <sub>4</sub> /mt)	9.7 g CH <sub>4</sub> per mt
365.25	= Conversion factor (day/year)	365.25
10 <sup>-6</sup>	= Conversion from g to mt	10 <sup>-6</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>12</sup>

Source: 2006 IPCC Guidelines for National Greenhouse Gas Inventories, Volume 5: Waste, Chapter 5: Incineration and Open Burning of Waste, Section 5.4.2, page 5.20. See: [http://www.ipcc-nggip.iges.or.jp/public/2006gl/pdf/5\\_Volume5/V5\\_5\\_Ch5\\_IOB.pdf](http://www.ipcc-nggip.iges.or.jp/public/2006gl/pdf/5_Volume5/V5_5_Ch5_IOB.pdf)

<sup>12</sup> See Appendix GWP for value.

## WW.5 Stationary Nitrous Oxide Emissions from Combustion of Biosolids and Sludges

### Introduction

This section provides equations for calculating the stationary N<sub>2</sub>O emissions from the combustion of biosolids and sludges produced by treatment plant processes based on site-specific data. There is no alternative method based solely on population. The method provides a description and appropriate default values (where applicable) for each term in the following equation.

As mentioned before, the CO<sub>2</sub> emissions from this source are part of the short-term carbon cycle. The methodologies to calculate these emissions are contained in the Power Generation chapter of this Protocol, and should be used when these fuels are used to generate power for export. When these fuels are burned to meet internal facility power needs or for purposes other than exporting power, the methods in this section should be used.

To calculate the stationary N<sub>2</sub>O emissions from the combustion of treatment plant residuals please follow *Method WW.5 Stationary Nitrous Oxide Emissions from Combustion of Biosolids and Sludges* if process information is available. If no process information is available, it is not possible to calculate emissions from this source. Also, this factor is based on a wet weight basis. If the dry weight is reported and the percent by weight of water is known after the dewatering step, the user should back-calculate the wet weight and then perform the calculations.

Larger municipalities often employ a portfolio of methods to affect final disposal of their WWTP residuals. Incineration may be one of several options used by a municipality to diversify their options. Therefore, it is not always the case that 100% of the residuals will be incinerated. The user of this protocol should verify that the mass of material entered into the equation accurately reflects the mass incinerated and not just blindly assume all the facility's residuals are processed that way.

Please note that if you are generating power or heat at your wastewater treatment facility and the electricity and/or heat are consumed entirely within the facility, you should report the combustion emissions from generating that power in Appendix F: Wastewater Emission Activities and Sources, not in Appendix C: the Built Environment Emissions Activities and Sources. If you generate power that is distributed outside your facility, report those emissions in Appendix C: the Built Environment Emissions Activities and Sources.

Finally, site-specific source test information using methods developed or approved by regulatory agencies is often better than any of these methods. Please note that N<sub>2</sub>O is NOT

considered the same as NO<sub>x</sub>, which is a criteria pollutant<sup>13</sup>, so a facility should not use NO<sub>x</sub> information to estimate their N<sub>2</sub>O emissions.

### WW.5 Data Needs

- Measured mass of biosolids or sludges sent to incineration, wet weight (mt/day.)

### WW.5 Calculation Based on the Wet Weight of Material Combusted

The method presented consists of the following two steps:

**Step 1:** Determine the mass of residuals combusted per day. This is the total mass in kg of the wet weight of sludges or biosolids combusted.

**Step 2:** Enter above variables into *Equation WW.5*. Use the default emission factor for g N<sub>2</sub>O per mt wet weight material combusted, GWP, and unit conversions. Enter these values into *Equation WW.5* to calculate stationary N<sub>2</sub>O emissions from the combustion of treatment plant residuals in mtCO<sub>2</sub>e.

<b>Equation WW.5 N<sub>2</sub>O Emissions from the Combustion of Wastewater Treatment Plant Residuals on a Wet Weight Basis</b>		
<i>Annual N<sub>2</sub>O emissions = (Wet Weight × EF<sub>N<sub>2</sub>O</sub> × 365.25 × 10<sup>-6</sup>) × GWP</i>		
Where:		
Description		Value
Annual N <sub>2</sub> O emissions	= Total annual N <sub>2</sub> O emitted by residuals combustion (mtCO <sub>2</sub> e)	Result
Wet Weight	= Wet weight of sludges or biosolids incinerated (mt/day)	User Input
EF <sub>N<sub>2</sub>O</sub>	= N <sub>2</sub> O emission factor (g N <sub>2</sub> O /mt)	900 g N <sub>2</sub> O per mt
365.25	= Conversion factor (day/year)	365.25
10 <sup>-6</sup>	= Conversion from g to mt	10 <sup>-6</sup>
GWP <sub>N<sub>2</sub>O</sub>	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>14</sup>
Source: 2006 IPCC Guidelines for National Greenhouse Gas Inventories, Volume 5: Waste, Chapter 5: Incineration and Open Burning of Waste, Section 5.4.3, page 5.21 and 5.22. See: <a href="http://www.ipcc-nggip.iges.or.jp/public/2006gl/pdf/5_Volume5/V5_5_Ch5_IOB.pdf">http://www.ipcc-nggip.iges.or.jp/public/2006gl/pdf/5_Volume5/V5_5_Ch5_IOB.pdf</a>		

<sup>13</sup> The South Coast Air Quality Management District in their Rule 1110.2 defines NO<sub>x</sub> as “OXIDES OF NITROGEN (NO<sub>x</sub>) means nitric oxide and nitrogen dioxide.” See: <http://www.aqmd.gov/rules/reg/reg11/r1110-2.pdf>, §(c)(13).

<sup>14</sup> See Appendix GWP for value.

## Process Emissions<sup>15</sup>

### WW.6 Process Methane Emissions from Wastewater Treatment Lagoons

#### Introduction

This section provides equations for calculating the process CH<sub>4</sub> emissions from lagoons based on site-specific data of the BOD<sub>5</sub> load. The method provides a description and an appropriate default value (where applicable) for each term in the following equations. This methodology is adapted from the LGO protocol and the EPA *Inventory of U.S. Greenhouse Gas Emissions and Sinks (1990-2010)*.

Lagoons treat wastewater through a combination of biological, physical and chemical processes. Most of the treatment occurs naturally but some systems include aeration devices to increase the amount of oxygen in the water, thereby making the treatment more efficient. Both aerobic and anaerobic fermentation can occur in a lagoon environment. It is only during the anaerobic phase of this process that CH<sub>4</sub> is produced.

To calculate the fugitive CH<sub>4</sub> emissions associated with lagoons please follow *Method WW.6*. This is the recommended method. If the data for WW.6 is unavailable, follow the alternate *Method WW.6 (alt)* to estimate the emissions based on population served by the lagoon.

Regardless of the methodology used to determine CH<sub>4</sub> emissions, the user should also calculate N<sub>2</sub>O emissions from any nitrogen discharged from the lagoon into the receiving waters using *Method WW.12.a* or *WW.12.b*.

#### WW.6 Data Needs

Below are the data inputs needed to collect in order to estimate the process CH<sub>4</sub> emitted by a community's wastewater treatment lagoons:

If Process Information is Available:	BOD <sub>5</sub> load (the amount of BOD <sub>5</sub> treated per day) AND Fraction of BOD <sub>5</sub> removed in primary treatment (FP), if applicable ( <i>Method WW.6</i> )
If Only Population Served is Available:	Population ( <i>Method WW.6.(alt)</i> )

<sup>15</sup> Note that this classification differs from the Clean Air Act, which considers emissions from these types of sources to be fugitive. According to 40 CFR Ch. I, section 70.2, fugitive emissions are defined as those emissions which could not reasonably pass through a stack, chimney, vent, or other functionally equivalent opening.

**WW.6 Calculation if BOD<sub>5</sub> Load and Fraction of BOD<sub>5</sub> Removed in Primary Treatment (if applicable) are Known**

**WW.6 Data Needs**

- BOD<sub>5</sub> load (the amount of BOD<sub>5</sub> treated per day)
- Fraction of BOD<sub>5</sub> removed in primary treatment (FP), if applicable

**WW.6 Calculation Method**

The method presented consists of the following three steps:

**Step 1:** Determine the amount of BOD<sub>5</sub> treated per day. BOD<sub>5</sub> is the amount of dissolved oxygen consumed in five days of biological decomposition. Users should be able to obtain this value (in kg/day) from the agency that oversees the lagoon.

**Step 2:** Determine the fraction of BOD<sub>5</sub> removed in primary treatment. Lagoons may have a primary treatment process, which removes some of the biologically dissolved oxygen. In order to get an accurate emission estimation, users must determine the BOD<sub>5</sub> load sent to the lagoon by determining the fraction of BOD<sub>5</sub> removed in primary treatment (FP). If there is no primary treatment, FP is zero.

**Step 3:** Enter above variables into *Equation WW.6* Use the default values for B<sub>0</sub> and MCF<sub>a</sub>, GWP, and unit conversions. Enter these values into *Equation WW.6* to calculate CH<sub>4</sub> emissions from a community's lagoon(s) in mtCO<sub>2</sub>e

<b>Equation WW.6 Methane Emissions from Lagoons</b>		
<i>Annual CH<sub>4</sub> emissions = (BOD<sub>5</sub> load × (1-FP) × Bo × MCF<sub>a</sub> × 365.25 × 10<sup>-3</sup>) × GWP</i>		
Where:		
Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by lagoon (mtCO <sub>2</sub> e)	Result
BOD <sub>5</sub> load	= Amount of BOD <sub>5</sub> treated per day (kgBOD <sub>5</sub> /day)	User input
FP	= Fraction of BOD <sub>5</sub> removed in primary treatment	User input
Bo	= Maximum CH <sub>4</sub> producing capacity for domestic wastewater (kg CH <sub>4</sub> /kg BOD <sub>5</sub> removed)	0.6
MCF <sub>a</sub>	= CH <sub>4</sub> correction factor for anaerobic systems	0.8
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>16</sup>
Source: As listed in LGO protocol Equation 10.3 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2007, Chapter 8, 8-7 (2009)		

<sup>16</sup> See Appendix GWP for value.

## **WW.6 Alternate Method for Methane Emissions from Lagoons if Only the Population is Known**

If site-specific data on average BOD<sub>5</sub> load and fraction of BOD<sub>5</sub> removal during primary treatment are not available, the alternative methodology WW.6.b should be employed. The only data required for this methodology is the population served by the lagoon. The methodology also includes a factor for wastewater discharge from industrial or commercial sources –  $F_{ind-com}$ . This factor should only be used if the commerce or industries in a user's community are "significant industrial users," according to the EPA's National Pretreatment program.<sup>17</sup> A "significant" industrial user" includes:

1. All users subject to categorical pretreatment standards under 40 CFR 403.6 and 40 CFR chapter I, subchapter N, except those designated as 'non-significant categorical industrial users' (see Box. 1 on page 8 for non-significant definition); and
2. Any other industrial user that discharges an average of 25,000 gallons per day (gpd) or more of process wastewater (excluding sanitary, noncontact cooling, and boiler blowdown wastewater).

If a facility does not have significant industrial or commercial wastewater inputs, set the  $F_{ind-com}$  term to 1 in these equations.

### **WW.6 (alt) Data Needs**

- Population served by the lagoon (P)

### **WW.6 (alt) Calculation Method**

The method presented consists of the following two steps:

**Step 1:** Determine the population served by the lagoon. Lagoon CH<sub>4</sub> emissions can be estimated based upon the size of the population that is served by the lagoon.

**Step 2:** Enter above variables into *Equation WW.6.b*. Use the provided default values for  $F_{ind-com}$ , BOD<sub>5</sub> FP, Bo MCF<sub>a</sub>, GWP, and unit conversion factors. Enter these values into *Equation WW.6.b* to calculate CH<sub>4</sub> emissions from a community's lagoon(s) in mtCO<sub>2e</sub>. If the lagoon does not treat wastewater from significant industrial or commercial sources, use 1 for  $F_{ind-com}$ .

---

<sup>17</sup> US EPA Introduction to the National Pretreatment Program. June 2011

**Equation WW.6.(alt) Alternate Methane Emissions from Lagoons**

$$\text{Annual CH}_4 \text{ emissions} = ((P \times F_{ind-com}) \times BOD_5 \text{ load} \times (1-FP) \times Bo \times MCF_a \times 365.25 \times 10^{-3}) \times GWP$$

Where:

Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by lagoon (mtCO <sub>2</sub> e)	Result
P	= Population served by lagoon	User Input
F <sub>ind-com</sub>	= Factor for significant industrial and commercial co-discharge waste (see definition above)	1.25
Description		Value
BOD <sub>5</sub> load	= Amount of BOD <sub>5</sub> treated per day (kg BOD <sub>5</sub> /person/day)	0.090
F <sub>p</sub>	= Fraction of BOD <sub>5</sub> removed in primary treatment	0.325
Bo	= Maximum CH <sub>4</sub> producing capacity for domestic wastewater (kg CH <sub>4</sub> /kg BOD <sub>5</sub> )	0.6
MCF <sub>a</sub>	= CH <sub>4</sub> correction factor for anaerobic systems	0.8
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>18</sup>

Source: As listed in LGO protocol Equation 10.4 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2007, Chapter 8, 8-7 (2009); except F<sub>p</sub>: Tchobanoglous, G., F.L. Burton, and H.D. Stensel, Wastewater Engineering: Treatment and Reuse, p. 396, 4<sup>th</sup> Edition (2003).

<sup>18</sup> See Appendix GWP for value.

## WW.7 Process Nitrous Oxide Emissions from Wastewater Treatment Plants with Nitrification or Denitrification

### Introduction

This section provides equations for calculating the process N<sub>2</sub>O emissions from WWTPs based on the population served by the WWTPs. Use *Method WW.7* for centralized WWTPs that utilize nitrification or denitrification or decentralized systems that utilize aeration basins with nitrification or denitrification. This includes WWTPs or aeration basins that support transient (such as in the summer) or complete nitrification or denitrification. The method provides a description and an appropriate default value (where applicable) for each term in the following equation. If the WWTP (or aeration basin) does not support any nitrification or denitrification then follow *Method WW.8 Process Emissions from All other Wastewater Treatment Plants*. If a user is uncertain whether or not a treatment plant employing nitrification or denitrification serves the user's community, the user should assume that it does not. In this case, skip this section and proceed to section *WW.8 Process Emissions from all other Wastewater Treatment Plants*.<sup>19</sup>

The  $F_{\text{ind-com}}$  term accounts for industrial and commercial discharges into the WWTP in *Equations WW.7* and *WW.8*. This factor should only be used if the commerce or industries are considered 'significant industrial' users. According to the EPA's National Pretreatment program<sup>20</sup> a 'significant user' includes (1) all users subject to categorical pretreatment standards under 40 CFR 403.6 and 40 CFR chapter I, subchapter N, except those designated as 'non-significant categorical industrial users' (see Box.1 on page 8); and (2) any other industrial user that discharges an average of 25,000 gpd or more of process wastewater (excluding sanitary, noncontact cooling, and boiler blowdown wastewater). If the facility does not have wastewater inputs from significant industrial or commercial sources, then set the  $F_{\text{ind-com}}$  term to 1 in these equations.

### WW.7 Data Needs

- Population served by the WWTP (P)

---

<sup>19</sup> The vast majority of WWTP in the United States do not employ NDN. According to the U.S. EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990–2009, page 8-14, only 2.4 million people are served by nitrification/denitrification. See: <http://www.epa.gov/climatechange/emissions/downloads11/US-GHG-Inventory-2011-Chapter-8-Waste.pdf>

<sup>20</sup> US EPA Introduction to the National Pretreatment Program. June 2011



### WW.7 Calculation Method

The method presented consists of the following three steps:

**Step 1:** Determine the population served by the WWTP (or aeration basin).

**Step 2:** Determine if significant amounts of industrial wastewater are discharged to the community’s municipal treatment system (see definition of ‘significant’ above). If the community has wastewater from significant users then set the  $F_{ind-com}$  term to 1.25. If the facility does not have significant levels of industrial or commercial nitrogen wastewater inputs then set the  $F_{ind-com}$  term to 1.

**Step 3:** Enter above variables into *Equation WW.7*. Use the provided default values for  $F_{ind-com}$ , EF, GWP, and unit conversions to calculate N<sub>2</sub>O emissions.

<b>Equation WW.7 N<sub>2</sub>O Process Emission from Wastewater Treatment Plants (or aeration basin) that Uses Nitrification or Denitrification</b>		
<i>Annual N<sub>2</sub>O emissions = ((P × F<sub>ind-com</sub>) × EF × 10<sup>-6</sup>) × GWP</i>		
Where:		
Description		Value
Annual N <sub>2</sub> O emissions	= Total annual N <sub>2</sub> O emitted by WWTP processes (mtCO <sub>2</sub> e)	Result
P	= Population served by the WWTP	User input
$F_{ind-com}$	= Factor for high nitrogen loading of industrial or commercial discharge	1.25
$F_{ind-com}$	= Factor for insignificant industrial or commercial discharge	1
EFnit/denit	= Emission factor for a WWTP with nitrification or denitrification (g N <sub>2</sub> O/person / year)	7
$10^{-6}$	= Conversion from g to mt (mt/g)	$10^{-6}$
GWP <sub>N<sub>2</sub>O</sub>	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>21</sup>
Source: As listed in LGO protocol Equation 10.7 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1890-2007, Chapter 8, 8-13 (2009)		

<sup>21</sup> See Appendix GWP for value.

## WW.8 Process Nitrous Oxide Emissions from Wastewater Treatment Plants without Nitrification or Denitrification

### Introduction

This section provides equations for calculating the process N<sub>2</sub>O emissions from all other WWTPs that do not support transient or complete nitrification or denitrification based on the population served by the WWTP. *Method WW.8* can be used to approximate the emissions from non-nitrifying or denitrifying systems, and similar cluster package systems, which mimic, on a smaller scale, non-nitrifying centralized WWTP. The approach in this section is the default condition if a user is uncertain if a plant supporting nitrification or denitrification serves the user's community.

### **Uncertainties in Calculations and Emerging Information:**

A recent survey investigating N<sub>2</sub>O emissions from select WWTPs supported by the Water Environment Research Foundation suggests that WWTPs not designed for nitrification but nitrified transiently could be potentially higher emitters of N<sub>2</sub>O than WWTPs designed and operated to nitrify and denitrify<sup>22</sup>. These preliminary findings are in contrast to the relative magnitudes of the two emission factors used in the above section.

Additionally, a high degree of spatial and temporal variability in N<sub>2</sub>O emissions has been consistently documented<sup>23</sup>, which cannot be captured by single emission factors as used in the calculations above. This variability implies that the greatest accuracy will not be achieved with these formulas, but with either sophisticated computer models under development or through comprehensive on-site source testing.

### WW.8 Data Needs

Below are the data inputs needed to collect in order to estimate the N<sub>2</sub>O process emissions produced by a WWTP (or cluster package system) that does not use nitrification or denitrification:

- Population served by the WWTP (P)

### WW.8 Calculation Method

The method presented consists of the following three steps:

**Step 1:** Determine the population size served by the WWTP (or aeration basin).

---

<sup>22</sup> Ahn, J. H., Kim, S., Park, H., Rahm, B., Pagilla, K., Chandran, K. N<sub>2</sub>O Emissions from Activated Sludge Processes, 2008-2009: Results of a National Monitoring Survey in the United States. *Environ. Sci. Technol.* 2010;44(12): 4505-4511. This study was derived from research that has yet to be finalized and thus has not been vetted.

<sup>23</sup> Ahn, J.-H., Kim, S., Pagilla, K., Katehis, D., Chandran, K. Spatial and temporal variability in N<sub>2</sub>O generation and emission from full-scale BNR and non-BNR processes. *Wat. Environ. Res.* 2010;82(12): 2362-2372.

**Step 2:** Determine whether the user’s facility has significant industrial or commercial wastewater inputs. According to the EPA’s National Pretreatment program<sup>24</sup> a ‘significant industrial user’ includes (1) all users subject to categorical pretreatment standards under 40 CFR 403.6 and 40 CFR chapter I, subchapter N, except those designated as ‘non-significant categorical industrial users’ (see Box. 1 on page 8); and (2) any other industrial user that discharges an average of 25,000 gpd or more of process wastewater (excluding sanitary, noncontact cooling, and boiler blowdown wastewater). If the user’s community does have significant industrial users then set the  $F_{ind-com}$  term to 1.25. If the user’s community does not have significant inputs, then set the  $F_{ind-com}$  term to 1.

**Step 3:** Enter above variables into *Equation WW.8*. Use the provided default values for  $F_{ind-com}$ , EF, GWP and unit conversions to calculate  $N_2O$  emissions.

<b>Equation WW.8 <math>N_2O</math> Process Emissions from Wastewater Treatment Plants (or aeration basin) without nitrification or denitrification</b>		
<i>Annual <math>N_2O</math> emissions = <math>((P \times F_{ind-com}) \times EF \times 10^{-6}) \times GWP</math></i>		
Where:		
Description		Value
Annual $N_2O$ emissions	= Total annual $N_2O$ emitted by WWTP processes (mtCO <sub>2</sub> e)	Result
P	= Population served by the WWTP	User input
$F_{ind-com}$	= Factor for high nitrogen loading of industrial or commercial discharge	1.25
$F_{ind-com}$	= Factor for insignificant industrial or commercial discharge	1
EF <sub>w/o nit/denit</sub>	= Emissions factor for a WWTP without nitrification or denitrification(g $N_2O$ / person / year)	3.2
$10^{-6}$	= Conversion from g to mt (mt/g)	$10^{-6}$
GWP <sub><math>N_2O</math></sub>	= Global Warming Potential; conversion from mt of $N_2O$ into mt of CO <sub>2</sub> equivalents	GWP <sup>25</sup>
Source: As listed in LGO protocol Equation 10.7 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1890-2007, Chapter 8, 8-13 (2009)		

<sup>24</sup> US EPA Introduction to the National Pretreatment Program. June 2011

<sup>25</sup> See Appendix GWP for value.

## WW.9 Process Carbon Dioxide Emissions from the Use of Fossil-Fuel-Derived Methanol for Biological Nitrogen Removal

### Introduction

This section provides equations for calculating anthropogenic CO<sub>2</sub> emissions from the use of fossil-fuel-derived methanol for biological nitrogen removal. If the user's WWTP uses methanol in the treatment process, follow *Method WW.9* to estimate anthropogenic CO<sub>2</sub> emissions from the methanol. Some wastewater treatment plants use carbon sources other than methanol for nitrogen removal. These sources may be fossil derived or biomass derived. Evaluating emissions from these sources is an area for future development.

Under current protocols, natural gas purveyors do not account for having unsequestered natural gas CH<sub>4</sub>; instead entities burning that gas are encouraged to account for its emission as a direct (Scope 1) GHG emission. The manufacturing Scope 3 emission factor of 0.67 kg CO<sub>2</sub>e/kg of methanol (IPCC, 2006) is considerably lower than the stoichiometric factor of 1.37 (molecular weight of CO<sub>2</sub>, 44.01, divided by the molecular weight of CH<sub>3</sub>OH, 32.04) and as such cannot account for having unsequestered the fossil fuel carbon. As such entities may wish to account for the anthropogenic CO<sub>2</sub> emissions associated with the process use of fossil-fuel-derived methanol for denitrification or biological phosphorus removal.

If methanol is needed for nitrogen removal, please be aware that any changes to methanol use, without replacement with an alternate carbon source, may affect nitrogen discharged in the effluent. A portion of this effluent nitrogen will be converted to N<sub>2</sub>O, so a decrease in methanol use may result in increased N<sub>2</sub>O emissions. If the user calculates emissions from methanol use at the user's WWTP, the user must follow the recommended *Method WW.12.a* for *Fugitive Emissions from Effluent Discharge* based on N-Load. The alternate *Method WW.12.b* is based on population and will overestimate N<sub>2</sub>O emissions because it does not take into account that N<sub>2</sub>O emissions that may be reduced due to the addition of methanol in the WWTP.

Under this methodology, methanol carbon addition results in carbon disposition that is partitioned as follows:

- 80% is respired as anthropogenic CO<sub>2</sub> in the activated sludge process and the balance (20%; representative of a 20% net sludge value) is converted to cell mass. If a different actual sludge yield is known for a given WWTP, then that yield should be used, and a corresponding different percent respired CO<sub>2</sub> (respired percent CO<sub>2</sub> = 1 – percent sludge yield) should also be used.
- In plants with anaerobic digestion, 50% of the cell mass carbon (10% of the original methanol carbon) is converted to a combination of CO<sub>2</sub> and CH<sub>4</sub> with the CH<sub>4</sub> being fully oxidized and emitted as CO<sub>2</sub> in either CHP equipment or at waste gas flares.
- In plants with solids combustion (incineration, gasification or other thermal destruction

technologies) 100% of the cell mass carbon (20% of the original carbon) is fully oxidized to CO<sub>2</sub>.

- In plants with raw sludge disposal, no additional CO<sub>2</sub> emissions exist on site – instead some emissions may occur as scope 3 emissions off site.

**WW.9 Data Needs**

- Methanol load (methanol load); amount of chemical used per day in mtCH<sub>3</sub>OH/day
- Treatment type (F), i.e. raw solids disposal, anaerobic digestion, or solids combustion

**WW.9 Calculation Method**

The following calculation is recommended to calculate the direct (Scope 1) CO<sub>2</sub> emissions from methanol use:

- Step 1:** Determine the amount of neat chemical in mtCH<sub>3</sub>OH used per day at the WWTP. This information should be available by contacting the treatment facility.
- Step 2:** Determine the type of sludge treatment at the facility—raw solids disposal, anaerobic digestion, or solids combustion. Each of these treatment options has a different factor associated with it. Choose the factor that matches the user’s facility.
- Step 3:** Use *Equation WW.9* to estimate annual CO<sub>2</sub> emissions associated with the methanol used at the WWTP along with the values identified in steps 1 and 2. *Equation WW.9* provides conversion factors to complete this calculation.

<b>Equation WW.9 CO2 Emission from Methanol Use</b>		
<i>Annual CO<sub>2</sub> emissions = Methanol Load *F *(44.01/32.04) *GWP *365.25</i>		
Where:		
Description		Value
Annual CO <sub>2</sub> emissions	= Total annual CO <sub>2</sub> emitted (mtCO <sub>2</sub> e)	Result
Methanol load	= Amount of neat chemical used per day (mt CH <sub>3</sub> OH/day)	User Input
F	= Factor to be applied based on WWTP’s sludge treatment type: <ul style="list-style-type: none"> <li>• Raw Solids Disposal      80%</li> <li>• Anaerobic Digestion      90%</li> <li>• Solids Combustion      100%</li> </ul>	0.80, 0.90, 1.0
44.01/32.04	= Molecular weight ratio of 44.01 (for CO <sub>2</sub> ) to 32.04 (for CH <sub>3</sub> OH)	1.37
GWP	= Global Warming Potential for CO <sub>2</sub>	1
365.25	= Conversion factor from days to year	365.25

## **WW.10 Process Emissions from Cluster Package Systems**

Cluster package systems operate like small-scale centralized WWTP that do not use nitrification or denitrification. If the community utilizes cluster package systems to treat its wastewater, follow method *WW.8 Process Emissions from all other Wastewater Treatment Plants* to calculate the N<sub>2</sub>O emissions from a cluster package system.

# Fugitive Emissions

## **WW.11 Fugitive Methane Emissions from Septic Systems**

### **Introduction**

This section provides equations for calculating the fugitive CH<sub>4</sub> emissions from septic systems based on BOD<sub>5</sub> load. The method provides a description and an appropriate default value (where applicable) for each term in the following equations.

Septic tanks collect wastewater on site and process it in underground tanks usually owned by private, residential owners. Conditions in the tank are anaerobic since the sewage in the system is not exposed to air. Under these anaerobic conditions, microorganisms biodegrade the soluble organic material found in waste. Some CH<sub>4</sub> produced during this degradation escapes from the septic systems into the atmosphere. The conversion to CH<sub>4</sub> is incomplete due to cold temperatures and other factors in the tanks. These systems are not optimized for CH<sub>4</sub> production and therefore are less efficient than theoretically possible.

To calculate the fugitive CH<sub>4</sub> emissions associated with the user's septic systems please follow *Method WW.11*. This recommended method is based on data on the BOD<sub>5</sub> load treated per day by the septic systems. Many communities may not have access to this data; if BOD<sub>5</sub> load data is not available then use alternate *Method WW.11.(alt)* to estimate the fugitive emissions based on population served by septic systems.

N<sub>2</sub>O emissions from septic systems are negligible and therefore no method has been included here.

### **WW.11 Data Needs**

Below are the data inputs needed to collect in order to estimate the fugitive CH<sub>4</sub> emitted by septic systems:

If Process Information is Available:	BOD <sub>5</sub> load (the amount of BOD <sub>5</sub> treated per day) <i>(Method WW.11)</i>
If Only Population Served is Available:	Population <i>(Method WW.1.(alt))</i>

## **WW.11 Fugitive Methane Emissions from Septic Systems if BOD<sub>5</sub> Load is Known**

### **WW.11 Data Needs**

- BOD<sub>5</sub> load (the amount of BOD<sub>5</sub> treated per day)

### **WW.11 Calculation Method**

The method presented consists of the following two steps:

**Step 1:** Determine the amount of BOD<sub>5</sub> treated per day. BOD<sub>5</sub> is the amount of dissolved oxygen consumed in five days of biological decomposition. A user should be able to get this value (in kg/day) from the agency that oversees septic systems.

**Step 2:** Plug into *Equation WW.11* Use the default values for B<sub>o</sub> and MCF<sub>s</sub>,GWP, and unit conversions. Plug these values into *Equation WW.11* to calculate CH<sub>4</sub> emissions from septic system in mtCO<sub>2</sub>e.

<b>Equation WW.11 Methane Emissions from Septic Systems</b>		
<i>Annual CH<sub>4</sub> emissions = (BOD<sub>5</sub> load × B<sub>o</sub> × MCF<sub>s</sub> × 365.25 × 10<sup>-3</sup>) × GWP</i>		
Where:		
Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by septic system annually (mtCO <sub>2</sub> e)	Result
BOD <sub>5</sub> load	= Amount of BOD <sub>5</sub> produced per day (kgBOD <sub>5</sub> /day)	User input
B <sub>o</sub>	= Maximum CH <sub>4</sub> producing capacity for domestic wastewater (kg CH <sub>4</sub> /kg BOD <sub>5</sub> removed)	0.6
MCF <sub>s</sub>	= CH <sub>4</sub> correction factor for septic systems <sup>26</sup>	0.22
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>27</sup>
Source: As listed in LGO protocol Equation 10.5 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2007, Chapter 8, 8-8 (2009).		

### **WW.11(alt)Alternative Method for Methane Emissions from Septic Systems if Only the Population is Known**

If data on the BOD<sub>5</sub> load is not available, then follow *Method WW.11(alt)*. The only data collection required for this methodology is the population served by septic systems in the user’s community.

#### **WW.11(alt) Data Needs**

- Population served by septic systems (P)

<sup>26</sup> Libia R Diaz-Valbuena, H.L. Leverenz, C. D. Cappa, G. Tchobanoglous, W.R. Horwath and J. L. Darby. 2011. “Methane, Carbon Dioxide, and Nitrous Oxide Emissions from Septic Tanks”. Environmental Science and Technology.

<sup>27</sup> See Appendix GWP for value.



## WW.11(alt) Calculation Method

The method presented consists of the following two steps:

**Step 1:** Determine the population served by the septic system. Septic system CH<sub>4</sub> emissions can be estimated based upon the size of the population that is served by them. If the user does not have records of the population in the community served by the septic system, the method provides some guidance below to help determine that number.

- Table WW.11(alt).1 lists the number of people that use septic systems in 47 different metropolitan areas. If the user's community is one of those metropolitan areas, use Table WW.11(alt).2 to find population served by septic system (P).
- If the user's community is not included in Table WW.11(alt).1 then calculate the number of people served by septic systems by multiplying the population of the community by the rural/ urban default percentages for septic tanks from Table WW.11(alt).2. These default percentages are from IPCC 2006.
- NOTE: The US Census Bureau defines urban and rural areas as follows:
  - Urbanized Areas (UAs) of 50,000 or more people;
  - Rural encompasses all population, housing, and territory not included within an urban area.

**Step 2:** Enter above variables into *Equation WW.11(alt)*. Use the population served by septic systems and the provided default values for BOD<sub>5</sub>, Bo MCF<sub>5</sub>,GWP, and unit conversions. Enter these values into *Equation WW.11(alt)* to calculate CH<sub>4</sub> emissions from septic systems in mtCO<sub>2</sub>e.

<b>Box WW.11(alt).1 Septic Systems in Metropolitan Areas<sup>28</sup></b>				
Area	Year	Housing units with Septic System [in thousands]	Average number of people per household	Population served by septic (P)
Anaheim-Santa Ana, CA PMSA	2002	3.3	2.88	9.52E+03
Atlanta, GA MSA	2004	358.7	2.58	9.26E+05
Baltimore, MD MSA	2007	143.8	2.49	3.58E+05
Birmingham, AL MSA	1998	137.5	2.49	3.43E+05
Boston, CMSA	2007	175.7	2.41	4.23E+05
Buffalo, NY CMSA	2002	55	2.43	1.33E+05
Charlotte, NC-SC MSA	2002	178.7	2.52	4.51E+05
Chicago, IL PMSA	2009	138.5	2.61	3.61E+05
Cincinnati, OH-KY-IN PMSA	1998	85.5	2.51	2.15E+05
Cleveland, OH PMSA	2004	87.4	2.44	2.13E+05
Columbus, OH MSA	2002	75.4	2.50	1.89E+05
Dallas, TX PMSA	2002	82.5	2.73	2.26E+05
Denver, CO MSA	2004	31.5	2.53	7.96E+04
Detroit, MI PMSA	2009	219.2	2.50	5.48E+05
Ft. Worth-Arlington, TX PMSA	2002	32.2	2.71	8.72E+04
Hartford, CT MSA	2004	115.1	2.48	2.85E+05
Houston, TX PMSA	2007	177.6	2.73	4.85E+05
Indianapolis, IN MSA	2004	119.4	2.47	2.95E+05
Kansas City, MO-KS MSA	2002	61.9	2.44	1.51E+05
Los Angeles-Long Beach, CA PMSA	2003	42	2.89	1.21E+05
Memphis, TN-AR-MS MSA	2004	42.1	2.58	1.09E+05
Miami-Ft. Lauderdale, FL CMSA	2007	127	2.54	3.22E+05
Milwaukee, WI PMSA	2002	59.5	2.47	1.47E+05
Minneapolis-St. Paul, MN-WI MSA	2007	139.4	2.56	3.57E+05
New Orleans, LA MSA	2009	41.6	2.47	1.03E+05
New York-Nassau-Suffolk-Orange, NY PMSA	2009	383	2.43	9.29E+05
Norfolk-Virginia Beach-Newport News, VA MSA	1998	66.1	2.59	1.71E+05
Northern NJ PMSA	2009	196.5	2.56	5.03E+05
Oakland, CA PMSA	1998	12.7	2.60	3.30E+04
Oklahoma City, OK MSA	2004	81	2.47	2.00E+05
Philadelphia, PA-NJ PMSA	2009	171.4	2.48	4.25E+05
Phoenix, AZ MSA	2002	60.5	2.62	1.59E+05
Pittsburgh, PA MSA	2004	169	2.38	4.03E+05
Portland, OR-WA PMSA	2002	110.1	2.51	2.76E+05
Providence-Pawtucket-Warwick, RI-MA PMSA	1998	115.5	2.50	2.88E+05
Riverside-San Bernardino-Ontario, CA PMSA	2002	192.4	3.03	5.82E+05
Rochester, NY MSA	1998	96.9	2.52	2.45E+05

<sup>28</sup> If user believes numbers are not representative of their community, then they should use the default factors.

<b>Box WW.11(alt).1 Septic systems in Metropolitan Areas (continued)</b>				
Area	Year	Housing units with Septic System [in thousands]	Average number of people per household	Population served by septic (P)
Sacramento, CA PMSA	2004	78.3	2.63	2.06E+05
ST. Louis, MO-IL MSA	2004	118.3	2.42	2.86E+05
Salt Lake City, UT MSA	1998	10.5	3.01	3.16E+04
San Antonio, TX MSA	2004	75.7	2.69	2.04E+05
San Diego, CA MSA	2002	59.2	2.60	1.54E+05
San Francisco-Oakland, CA PMSA	1998	13.9	2.34	3.25E+04
San Jose, CA PMSA	1998	14.7	2.68	3.94E+04
Seattle-Everett, WA PMSA	2009	222.7	2.45	5.45E+05
Tampa-St. Petersburg, FL MSA	2007	155.9	2.31	3.60E+05
Washington, DC-MD-VA MSA	2007	195.6	2.51	4.90E+05

Source: US Census Bureau, See: <http://www.census.gov/hhes/www/housing/ahs/metropolitandata.html>

<b>Box WW.11(alt).2 Default proportion of population that utilizes septic tanks</b>		
	Rural	Urban*
United States	0.90	0.05
*Definitions <b>Urban</b> is defined as areas of 50,000 or more people; <b>Rural</b> is defined as all population, housing, and territory not included within an urban area.		
Source: 2006 IPCC Guidelines for National Greenhouse Gas Inventories, Chapter 6, Table 6.5		

**Equation WW.11(alt) Alternate Methane Emissions from Septic Systems**

$$\text{Annual CH}_4 \text{ emissions} = (P \times \text{BOD}_5 \text{ load} \times \text{Bo} \times \text{MCF}_s \times 365.25 \times 10^{-3}) \times \text{GWP}$$

Where:

Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by septic system (mtCO <sub>2</sub> e)	Result
P	= Population served by septic system	For some Metropolitan Areas see Table WW.11(alt) For all other areas multiply population of community by rural or urban default from Table WW.11(alt).2
BOD <sub>5</sub> load	= Amount of BOD <sub>5</sub> treated per day (kg BOD <sub>5</sub> /person/day)	0.090
Bo	= Maximum CH <sub>4</sub> producing capacity for domestic wastewater (kg CH <sub>4</sub> /kg BOD <sub>5</sub> )	0.6
MCF <sub>s</sub> <sup>29</sup>	= CH <sub>4</sub> correction factor for septic systems	0.22
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> equivalents	GWP <sup>30</sup>

Source: As listed in LGO protocol Equation 10.5 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2006, Chapter 8, 8-8 (2008).

<sup>29</sup> Libia R Diaz-Valbuena, H.L. Leverenz, C. D. Cappa, G. Tchobanoglous, W.R. Horwath and J. L. Darby. 2011. "Methane, Carbon Dioxide, and Nitrous Oxide Emissions from Septic Tanks". Environmental Science and Technology.

Jeannie L. Darby, et. al. 2010. *Evaluation of Greenhouse Gas Emissions from Septic Systems*. Water Environment Research Foundation DEC1R09

<sup>30</sup> See Appendix GWP for value.

## WW.12 Fugitive Nitrous Oxide Emissions from Effluent Discharge

### Introduction

This section provides equations for calculating the process N<sub>2</sub>O emissions from effluent discharge from WWTPs based on site-specific data or the population served by the WWTP. The method provides a description and an appropriate default value (where applicable) for each term in the following equations.

Effluent discharge is treated wastewater that flows out from a treatment facility or industrial plant and is discharged into waterways, lakes, or the ocean. Effluent discharge originating from a conventional wastewater treatment facility without advanced processes is treated to secondary treatment standards and is therefore called secondary effluent. Conventional WWTPs are not able to remove all of the nitrogen content in wastewater, leaving about 10% in the effluent (Scheehle 2001). However, N<sub>2</sub>O is only present in trace amounts (if at all) in the effluent, and most of the nitrogen is in other forms. Only when this nitrogen containing effluent reaches a natural watershed will indirect N<sub>2</sub>O emissions occur through side reactions. Using methodology from the EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990–2010, N<sub>2</sub>O emissions through these side reactions could make up to 95% of the total N<sub>2</sub>O generated from a WWTP.

To calculate the fugitive N<sub>2</sub>O emissions associated with effluent discharge from WWTPs please follow *Method WW.12 Fugitive Nitrous Oxide Emissions from Effluent Discharge*. If significant amounts of industrial wastewater are discharged to a community’s municipal treatment system, users should use the recommended method, *WW.12*. If the effluent nitrogen content is routinely measured by the user’s facility, use that number with *Equation WW.12*; this is the most accurate approach. If the data for *WW.12* is unavailable, follow *Method WW.12(alt)* to estimate the fugitive emissions based on population served by the WWTP.

If the user calculated the emissions due to methanol use in its WWTPs in *WW.9* please follow *Method WW.12 Fugitive N<sub>2</sub>O Emissions from Effluent Discharge*. Following *Method WW.12(alt)* will result in over-estimating emissions.

### WW.12 Data Needs

Below are the data inputs needed to collect in order to estimate the fugitive CH<sub>4</sub> emitted by septic systems:

If Process Information is Available:	Average total nitrogen discharged per day (Total N-load) ( <i>Method WW.12</i> )
If Only Population Served is Available:	Population AND Whether there is significant industrial or commercial input ( <i>Method WW.12.(alt)</i> )

**WW.12 Calculation if Average Total Nitrogen Discharged per Day (Total N-load) is Known**

**WW.12 Data Needs**

- Average total nitrogen discharged per day (Total N-load)

**WW.12 Calculation Method**

The method presented consists of the following two steps:

**Step 1:** Determine the average nitrogen discharged per day by the facility. The facility should maintain records of the N-load in their discharge.

**Step 2:** Enter above variables obtained and default values into *Equation WW.12*. Use the provided default values for N-load, GWP, and unit conversions. Enter these values along with the procured data into *Equation WW.12* to calculate N<sub>2</sub>O emissions from effluent in mtCO<sub>2</sub>e

<b>Equation WW.12 N<sub>2</sub>O Emission from Effluent Conversion</b>		
<i>Annual N<sub>2</sub>O emissions = (N-Load × EF<sub>effluent</sub> × 365.25 × 10<sup>-3</sup> × 44/28) × GWP</i>		
Where:		
Description		Value
N <sub>2</sub> O emissions	= Total annual N <sub>2</sub> O emitted by effluent conversion (mtCO <sub>2</sub> e)	Result
N-Load	= Average total nitrogen per day (kg N/day)	User input
EF <sub>effluent</sub>	= Emission factor (kg N <sub>2</sub> O-N/kg sewage-N discharged)	0.005 for river or stream discharge, 0.0025 for direct ocean discharge <sup>31</sup>
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
44/28	= Molecular weight ratio of N <sub>2</sub> O to N <sub>2</sub>	1.57
GWP <sub>N<sub>2</sub>O</sub>	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>32</sup>
Source: As listed in LGO protocol Equation 10.9 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2007, Chapter 8, 8-13 (2009)		

<sup>31</sup> Note, neither the IPCC nor the EPA have yet to distinguish between effluent conversion that occurs in rivers (and then subsequent conversion in estuaries), as opposed to conversion that only occurs in estuaries.

<sup>32</sup> See Appendix GWP for value.

## Alternative WW.12(alt) Nitrous Oxide Emissions from Effluent Discharge if Only the Population is Known

An alternative methodology has been provided for communities without site-specific N-load data. This method is based on population, and uses a default total nitrogen load factor of 0.026 kg N/person/day that was derived from the EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2006 as used in the LGO Protocol<sup>33</sup>. If there is a significant industrial wastewater contribution to a user's municipal treatment system, the population input of this equation must be adjusted. As stated above, significant industrial users are defined as (1) all users subject to categorical pretreatment standards under 40 CFR 403.6 and 40 CFR chapter I, subchapter N, except those designated as 'non-significant categorical industrial users' (see Box. 1 on page 8); and (2) any other industrial users that discharges an average of 25,000 gpd or more of process wastewater (excluding sanitary, noncontact cooling, and boiler blowdown wastewater).

### WW.12(alt) Data Needs

- Population served by the facility (P)
- Whether there is significant industrial or commercial input

### WW.12(alt) Calculation Method

The method presented consists of the following three steps:

**Step 1:** Determine the population served by the facility. When the other data is unavailable, the population served by that WWTP could be used to estimate N<sub>2</sub>O emissions from the effluent discharge. Where appropriate, a user may add the industrial-equivalent factor ( $F_{ind-com}$  1.25) to the domestic population if both are served by the WWTP. If a user's facility does not have industrial or commercial wastewater inputs then set the  $F_{ind-com}$  term to 1.

**Step 2:** Determine whether the WWTP employs nitrification or denitrification. If a WWTP employs nitrification or denitrification then the fraction of N removed by the plant can be estimated to 0.7. If the WWTP does not employ nitrification or denitrification, then 0.0 N is removed from the WWTP.

**Step 3:** Enter above variables obtained and default values into *Equation WW.12(alt)*. Use the provided default values for  $F_{int-com}$ , N-load, N uptake, BOD<sub>5</sub>, EF,  $F_{plant}$  (either with or without nitrification/ denitrification), GWP, and unit conversions. Enter these values along with the procured data into *Equation WW.12(alt)* to calculate N<sub>2</sub>O emissions from the effluent conversion of discharged nitrogen from a wastewater plant in mtCO<sub>2</sub>e

---

<sup>33</sup> The default total nitrogen load value is derived based on the following default values from US EPA Inventory of US Greenhouse Gas Emissions and Sinks: 1990-2006, Chapter 8, 8-14 and Table 8.11: Average US protein intake (41.9 kg/person-year) x default fraction of N in protein (0.16 kg N/kg protein) x factor for non-consumed protein added to water (1.4) / days per year (365.25) = 0.026 kg N/person/day.

**Equation WW.12.(alt) N<sub>2</sub>O Emission from Effluent Conversion when only Population Served by Wastewater Treatment Plant is Known**

$$\text{Annual N}_2\text{O emissions} = ((P \times F_{ind-com}) \times (\text{Total N load} - N \text{ uptake} \times \text{BOD}_5 \text{ load}) \times \text{EF effluent} \times 44/28 \times (1 - F_{plant nit/denit}) \times 365.25 \times 10^{-3}) \times \text{GWP}$$

Where:

Description		Value
N <sub>2</sub> O emissions	= Total annual N <sub>2</sub> O emitted by effluent (mtCO <sub>2</sub> e)	Result
P	= Population	User input
$F_{ind-com}$	= Factor for industrial or commercial discharge	1.25 (if applicable)
Total N-Load	= Average total nitrogen per day (kg N/person/day)	0.026 <sup>34</sup>
N uptake	= Nitrogen uptake for cell growth in <i>aerobic</i> systems (kg N/kg BOD <sub>5</sub> )	0.05
<b>OR</b>		
N uptake	= Nitrogen uptake for cell growth in <i>anaerobic or lagoon</i> systems (kg N/kg BOD <sub>5</sub> )	0.005
BOD <sub>5</sub>	= Amount of BOD <sub>5</sub> produced per person per day (kg BOD <sub>5</sub> /person/day)	0.090
EF	= Emission factor (kg N <sub>2</sub> O-N/kg sewage-N discharged)	0.005 for river or stream discharge, 0.0025 for direct ocean discharge <sup>35</sup>
44/28	= Molecular weight ratio of N <sub>2</sub> O to N <sub>2</sub>	1.57
$F_{plant nit/denit}$	= Fraction of nitrogen removed from the WWTP with nitrification/denitrification	0.7
<b>OR</b>		
$F_{plant}$	= Fraction of nitrogen removed from the WWTP without nitrification/denitrification	0.0
365.25	= Conversion factor (day/year)	365.25
$10^{-3}$	= Conversion from kg to mt (mt/kg)	$10^{-3}$
GWP	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>36</sup>

Source: As listed in LGO protocol Equation 10.10 from EPA Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2007, Chapter 8, 8-13 (2009); except Grady, C.P. L., Jr., G. T. Daigger, and H. C. Lim, *Biological Wastewater Treatment* p. 108-109, 644 2<sup>nd</sup> Edition (1999)

<sup>34</sup> The default total nitrogen load value is derived based on the following default values from US EPA Inventory of US Greenhouse Gas Emissions and Sinks: 1990-2006, Chapter 8, 8-14 and Table 8.11: Average US protein intake (41.9 kg/person-year) x default fraction of N in protein (0.16 kg N/kg protein) x factor for non-consumed protein added to water (1.4) / days per year (365.25) = 0.026 kg N/person/day.

<sup>35</sup> Note, neither the IPCC nor the EPA have yet to distinguish between effluent conversion that occurs in rivers (and then subsequent conversion in estuaries), as opposed to conversion that only occurs in estuaries.

<sup>36</sup> See Appendix GWP for value.



## WW.13 Attribution of Wastewater Emissions Outside of Operational Control

### Introduction

This section provides equations for attributing the portion of CH<sub>4</sub> and N<sub>2</sub>O emissions from WWTPs to their respective communities based upon proportioning population of the given community in question to the total population served by the WWTP. If a user's community has a significant commercial and/or industrial contribution (especially if the nitrogen loading is high), this method could underestimate the actual emissions. The method provides a description and an appropriate default value (where applicable) for each term in the following equations.

To calculate attributed CH<sub>4</sub> emissions associated with a user's community, follow *MethodWW.13<sub>CH4</sub> Attribution of Wastewater CH<sub>4</sub> Emissions*. To calculate attributed N<sub>2</sub>O emissions associated with a user's community, follow *MethodWW.13<sub>N2O</sub>*. Add the results from calculation *WW.13<sub>CH4</sub>* and *WW.13<sub>N2O</sub>* to get the total emissions attributed for a community's wastewater. Communities served by multiple wastewater treatment systems must apply *MethodWW.13<sub>CH4</sub>* (for CH<sub>4</sub>) and *MethodWW.13<sub>N2O</sub>* (for N<sub>2</sub>O) to each wastewater treatment system the community utilizes to get the total attributed emissions.

### WW.13<sub>CH4</sub> Attribution of Wastewater CH<sub>4</sub> Emissions

#### WW.13<sub>CH4</sub> Data Needs

- Population of community served by given WWTP (P)
- Total population the WWTP serves (P<sub>tot</sub>)
- Total CH<sub>4</sub> emissions from WWTP in mtCO<sub>2e</sub> (E)

#### WW.13<sub>CH4</sub> Calculation Method

The method presented consists of the following four steps:

**Step 1:** Determine the population served by given WWTP. For communities that are entirely served by one wastewater treatment facility, then P is the entire population of the community. For those populations served by multiple facilities, then P is the number of people served by the given facility

**Step 2:** Determine the total population the given WWTP serves. The number of people served by the facility can be found by contacting a user's wastewater treatment provider.

**Step 3:** Determine the Total CH<sub>4</sub> emissions from the WWTP. The total CH<sub>4</sub> emissions can also be found by using methods described earlier in this document, or by contacting the user's wastewater treatment provider. They can implement this protocol to calculate their total emissions.

**Step 4:** Enter above variables into *Equation WW.13<sub>CH4</sub>*. Use these values in *Equation WW.13<sub>CH4</sub>* to calculate the annual emissions attributed to the community from the given wastewater treatment facility

<b>Equation WW.13<sub>CH4</sub> Attributed CH<sub>4</sub> Emissions</b>		
<i>Attributed CH<sub>4</sub> Emissions = P/P<sub>tot</sub> * E</i>		
Where:		
Description		Value
Attributed CH <sub>4</sub> Emissions	= Annual CH <sub>4</sub> credited to the community (mtCO <sub>2</sub> e)	Result
P	= Population of community served by the given WWTP	User input
P <sub>tot</sub>	= Total population the WWTP serves	User input
E	= Total CH <sub>4</sub> produced by WWTP (mtCO <sub>2</sub> e)	User input
Source: Developed by ICLEI Staff and Wastewater Technical Advisory Committee		

### **WW.13<sub>N2O</sub> Attribution of Wastewater N<sub>2</sub>O Emissions**

This section provides equations for attributing the portion N<sub>2</sub>O emissions from WWTPs to their respective communities based upon proportioning population of the given community in question to the total population served by the WWTP. If the user’s community has a significant commercial and/or industrial contribution (especially if the nitrogen loading is high), this method could underestimate the actual emissions. The method provides a description and an appropriate default value (where applicable) for each term in the following equation.

#### **WW.13<sub>N2O</sub> Data Needs**

- Population of community served by given WWTP (P)
- Total population the WWTP serves (P<sub>tot</sub>)
- Total N<sub>2</sub>O emissions from WWTP in mtCO<sub>2</sub>e (E)

#### **WW.13<sub>N2O</sub> Calculation Method**

The method presented consists of the following four steps:

**Step 1:** Determine the population served by given WWTP. For communities that are entirely served by one wastewater treatment facility, then P is the entire population of the community. For those populations served by multiple facilities, then P is the number of people served by the given facility

**Step 2:** Determine the total population the given WWTP serves. The number of people served by the facility can be found by contacting the community’s wastewater treatment provider.

**Step 3:** Determine the Total N<sub>2</sub>O emissions from the WWTP. The total N<sub>2</sub>O emissions can also be found by using method described earlier in this document, or by contacting the user’s wastewater treatment provider. They can implement this protocol to calculate their total emissions.

**Step 4:** Enter above variables into *Equation WW.13<sub>N<sub>2</sub>O</sub>*. Use these values in *Equation WW.13<sub>N<sub>2</sub>O</sub>* to calculate the annual emissions attributed to the community from the given wastewater treatment facility

<b>Equation WW.13<sub>N<sub>2</sub>O</sub> Attributed N<sub>2</sub>O Emissions</b>		
<i>Attributed N<sub>2</sub>O Emissions = P/P<sub>tot</sub> * E</i>		
Where:		
Description		Value
Attributed N <sub>2</sub> O Emissions	= Annual N <sub>2</sub> O credited to the user's community (mtCO <sub>2</sub> e)	Result
P	= Population of community served by the given WWTP	User input
P <sub>tot</sub>	= Total population the WWTP serves	User input
E	= Total N <sub>2</sub> O produced by WWTP (mtCO <sub>2</sub> e)	User input
Source: Developed by ICLEI Staff and Wastewater Technical Advisory Committee		

## **WW.14 Energy-related Emissions Associated with Water Delivery and Treatment**

### **Introduction**

The consumption of water by a community's residents and businesses can have significant GHG implications depending on the source of water, distances and topography traversed in conveyance, and the treatment processes that occur before and after the end-use phase. Incorporating the relationship between water consumption and energy consumption in a GHG inventory allows a community to use water conservation measures as a GHG emissions reduction strategy.


The methods described in this section first account for the embodied energy and the subsequent GHG emissions impact of water consumption in a community inventory, the first steps in the community water cycle. Methods are implemented from a water use perspective. Therefore, double counting with GHG emission sources accounted for in other sectors may be likely. For example, stationary energy consumption at water treatment and distribution facilities within a community's boundary may be at risk for double counting. For this reason, GHG emissions from water consumption should not be summed with GHG emissions from other direct sources (i.e. stationary energy consumption).

Several processes exist which, when combined, provide for the total GHG emissions of a community's management of its potable water. Figure WW.14.1 illustrates the different energy consuming processes involved in the delivery and treatment of water. Note this method will address the first three elements of that cycle. The energy intensity of each of these processes and the volume of water passing through each will need to be known in order to accurately inventory emissions associated with water consumption. The degree to which each of the processes used to deliver your community's water is identified, and the energy intensity of each of those processes is known, will define the accuracy of the methods for determining the GHG emissions from water consumption.

Different water sources can have different fates in the cycle. In many states, a significant percentage of water comes from on-site sources. On-site sources of water often meet the needs of users in very close proximity to the source; hence the extraction/conveyance demands are insignificant. Also, for these systems, treatment is minimal and the water is consumed on-site so there are no distribution impacts. Therefore, the focus is centered on that fraction of the population served by public supplies from surface and groundwater.

It is common for communities to draw from a mixture of both groundwater and surface water. Groundwater sources require energy to extract the water from wells; surface waters require no extraction energy. Also, surface waters generally require more treatment than groundwater to bring the surface waters to drinking water standards. For the purposes of this method, the distribution energy demands for both supplies are the same.

Figure WW.14.1 Energy Consuming Processes in the Delivery and Treatment of Water<sup>37</sup>



Water supply requires energy for extraction in the case of ground water. Surface water does not require energy to supply. Energy use for conveyance applies to both ground water and surface water.

Water conveyance can be the most impactful element in the cycle. In California, communities in the south draw significant amounts of water from vast distances over elevated terrain. Nevertheless, even communities in Northern California can have a high energy demand associated with their water supply and distribution. Because of California’s unique energy demands, California users should refer to *Embedded Energy in Water Studies, Study 2: Water Agency and Function Component Study and Embedded Energy-Water Load Profiles*, Appendix B<sup>38</sup> if data is not available directly from your local water agency.

Energy consumption and resulting GHG emissions from the end-use phase are excluded. End Use consists of the electricity or fossil fuels used at community residences, commercial buildings or industrial facilities for heating, cooling, and final dispersal of water (when these require additional power inputs). End Use emissions will already be contained in calculations done in Appendix C: Built Environment Emission Activities and Sources. Emissions from water supply/conveyance, treatment and distribution *might* be accounted for in Appendix C (or

<sup>37</sup> Klein, Gary, Ricardo Amon, Shahid Chaudhry, Loraine White, et al. California’s Water-Energy Relationship: Final Staff Report. Nov. 2005. California Energy Commission. Available at:

<http://www.energy.ca.gov/2005publications/CEC-700-2005-011/CEC-700-2005-011-SF.PDF>

<sup>38</sup> Prepared by GEI Consultants/Navigant Consulting for the California Public Utilities Commission, August 31, 2010.

<ftp://ftp.cpuc.ca.gov/gopher-data/energy%20efficiency/Water%20Studies%202/Appendix%20B%20-%20Agency%20Profiles%20-%20FINAL.pdf>.

maybe just in part) if your water facilities are located within your community, however, in most cases, these facilities are spread out across numerous jurisdictions.

The water system components in each process in your water system that should be accounted for in this section may include:

- Water Supply & Conveyance:
  - Pumps to extract water from either a surface body of water or groundwater and to move the raw water any significant distance.
- Water Treatment:
  - Pumps and equipment to provide purification treatments such as UV disinfection, ozone treatment, membrane filtration, or chlorination.
- Water Distribution:
  - Pumps to send out and pressurize water in the local distribution system.

Methods for calculating the energy intensity for Wastewater Collection, Treatment and Distribution are found in WW.15.

Each of the processes listed above occur in facilities that consume energy for activities that are not directly related to or dependent on the volume of water processed at that facility. This includes things like lighting or other building energy functions. Properly benchmarking your water delivery system will help to ensure that these functions are accounted for such that process energy is readily available for this type of GHG inventory calculation. Many resources are available for benchmarking your system through the EPA Energy Star Program.<sup>39</sup> The end-use phase is excluded because energy consumption from that phase is captured in the stationary energy and electricity consumption sector, primarily from water heating.

### **Uncertainties and Limitations**

For users without site-specific information, this method combines state level usage with nationwide energy intensities and regional energy to GHG emission conversions, each with different vintages and different degrees of reliability. Users should be cautioned against using WW.14 to meet regulatory requirements such as those in federal or state mandatory reporting rules or, in California, CEQA. Although Lead Agencies in CEQA have the discretion to choose their preferred emissions estimation method, they must be able to justify why that method is the best for their project. Thus, tools designed to meet regulatory requirements such as EPA's Energy Star

---

<sup>39</sup> US EPA ENERGY STAR for Wastewater Plants and Drinking Water Systems.  
[http://www.energystar.gov/index.cfm?c=water.wastewater\\_drinking\\_water](http://www.energystar.gov/index.cfm?c=water.wastewater_drinking_water)

Portfolio Manager or CalEEMod<sup>40</sup> for CEQA may be more appropriate for that purpose. Other tools that are more comprehensive such as WESim<sup>41</sup> may be more suitable as well. The best results are from site-specific values that are better than any model regardless of the source.

### **Recommended Approach**

The recommended approach for calculating GHG emissions for water consumption, including water supply and wastewater treatment, utilizes community-specific energy consumed per unit of water for each process of the water system for a community's water consumption.

For communities without significant influence over these activities or those without resources to obtain specific information should use the method outlined below. Default values and assumptions for each required input are provided in Tables WW.14.1 – WW.14.5.

### **Method WW.14 Calculation of Upstream Emissions Associated with Water Supply, Conveyance, Treatment and Delivery**

#### **WW.14 Data Needs**

- Water Supply and Conveyance:
  - Percentage of self-supplied, groundwater and surface water
  - Population
  - Water use per capita
  - Default factor for groundwater energy intensity
  - Community specific energy to GHG emissions
  - General knowledge of water source (inside or outside community)

The method considers the energy intensity of groundwater extraction, and groundwater and surface water conveyance.

- Water Treatment:
  - Percentage of self-supplied, groundwater and surface water
  - Population
  - Water use per capita
  - Default factors for water treatment
  - Community specific energy to GHG emissions

The method considers only the energy intensity of surface water treatment since the energy intensities for self-supplied water and groundwater treatment are negligible.

- Water Distribution:

---

<sup>40</sup> CalEEMod was developed by the California Air Pollution Control Officers Association for purposes of estimating impacts of projects under CEQA and thus is valid only for California users. See: <http://caleemod.com/>

<sup>41</sup> <http://pacinst.org/resources/wesim/index.htm>

- Percentage of self-supplied, groundwater and surface water
- Population
- Water use per capita
- Default factor for groundwater energy intensity
- Community specific energy to GHG emissions

The method considers only the energy intensity of groundwater and surface water distribution since it is assumed that self-supplied is mainly used on-site and is not distributed to remote users.

### **WW.14 Calculation Method**

The method presented considers each element of the water cycle highlighted in Figure WW.14.1 individually and sums the conveyance, treatment, and distribution emissions at the end. Note the method assumes self-supplied waters have negligible emissions. These waters are generally obtained and used on-site with little need for treatment.

California users should refer to the report *Embedded Energy in Water Studies, Study 2: Water Agency and Function Component Study and Embedded Energy-Water Load Profiles*, Appendix B.<sup>42</sup> For most included water agencies, this report provides number of customers and population served, total water supplied, percentage of water from different sources, and energy intensity of these sources. Note that annual water supply in this report is often provided in units of AF, or Acre-feet. One acre-foot is equal to 325,851 gallons.

Figure WW.14.2 can guide the user through the steps required to calculate emissions from the management of water by a community.

In these methods, if a table or method calls for a size in units of million gallons (MG), that metric can be obtained by multiplying the per capita generation by the population and dividing by one million.


---

<sup>42</sup>Prepared by GEI Consultants/Navigant Consulting for the California Public Utilities Commission, August 31, 2010.

<ftp://ftp.cpuc.ca.gov/gopher-data/energy%20efficiency/Water%20Studies%202/Appendix%20B%20-%20Agency%20Profiles%20-%20FINAL.pdf>.



**FIGURE WW.14.2: Decision Tree for Reporting Electricity Use from Water Management within your Community**



## **WATER SUPPLY: EXTRACTION AND CONVEYANCE**

**Step 1:** Obtain the proportions of groundwater and surface water.

Refer to Table WW.14.1 for a state-by-state distribution if the community specific distribution is not known or obtainable.

**Step 2:** Multiply the total population of the community by the fraction receiving groundwater and surface water and the per capita use, (defaults available in table WW.14.1) to get the actual volume.

**Step 3:** Multiply the volume of groundwater for the community by the appropriate process energy consumed per unit of groundwater to calculate total energy consumed for groundwater extraction. Refer to Table WW.14.2 for groundwater extraction default energy intensities if the community specific value is not known. The low value in the table is the default since there is no median value. If the water table depth is known, multiply the depth in feet by 4.5 to yield energy intensity in kWh/million gallons.<sup>43</sup> The extraction energy for self-supplied and surface waters are assumed to be negligible.

**Step 4:** Multiply the volume of groundwater and surface water by the process energy consumed per unit of groundwater and/or surface water to calculate total energy consumed for its conveyance to the treatment facility. Refer to Table WW.14.3 for conveyance default energy intensities if the community specific value is not known. For water sourced within the community geographic boundary, use the median value of 110 kWh/MG. For waters sourced from beyond the geographic boundary of the community, use the median value of 3000 kWh/MG. Energy requirements for conveyance depend greatly on distance pumped and the change in elevation so low and high values can be used based on the judgment of the user<sup>44</sup>. Only deviate from the median if absolutely certain. The conveyance energy for self-supplied waters are assumed to be negligible.

California users should refer to the report *Embedded Energy in Water Studies, Study 2: Water Agency and Function Component Study and Embedded Energy-Water Load Profiles*, Appendix B for defaults.

**Step 5:** Multiply total energy consumed for extraction and conveyance by the appropriate GHG emissions factor for the community from Table WW.14.7, WW.14.8, or WW.14.9. See Appendix C, section BE.2 for guidance on choosing the appropriate factor.

## **WATER TREATMENT**

---

<sup>43</sup> Value/foot is calculated as an average of the values in Table WW.14.2.

<sup>44</sup> Implications of Future Water Supply Sources for Energy Demands, WaterReuse Research Foundation, 2012. See: <http://www.pacinst.org/resources/wesim/report.pdf>, page 22.

**Step 1:** Obtain the percentage of surface water.

Refer to Table WW.14.1 for a state-by-state distribution if the community specific distribution is not known or obtainable.

**Step 2:** Multiply the total population of the community by the fraction receiving surface water and the per capita use, (defaults available in table WW.14.2) to get the actual volume.

**Step 3:** Multiply the volume of surface water for the community by the appropriate process energy consumed per unit of treated surface water to calculate total energy consumed. Refer to Table WW.14.4 for treatment default energy intensities if the community specific value is not known. Assume that the treatment energy intensities for groundwater are negligible. In general, use the median values based on population multiplied by per capita water use. Facilities for pressure filtration and oxidation use the high values. For sand filtration use the low values. Only deviate from the median if absolutely certain

**Step 4:** Multiply total energy consumed for water treatment by the appropriate GHG emissions factor for the community from Table WW.14.7, WW.14.8, or WW.14.9. See Appendix C, section BE.2 for guidance on choosing the appropriate factor.

## **WATER DISTRIBUTION**

**Step 1:** Obtain the proportions of groundwater and surface water.

Refer to Table WW.14.1 for a state-by-state distribution if the community specific distribution is not known or obtainable.

**Step 2:** Multiply the total population of the community by the fraction receiving groundwater and surface water and the per capita use, (defaults in table WW.14.1) to get the actual volume.

**Step 3:** Multiply the volume of groundwater and surface water for the community by the appropriate process energy consumed per unit of distributed groundwater and/or surface water to calculate total energy consumed for distribution. Refer to Table WW.14.5 for distribution default energy intensities if the community specific value is not known. Distribution energy is highly dependent on distribution network topography and distance pumped. Assume distribution energy intensity is the same for water sourced from groundwater and surface water. High and low values are supplied for use based on the best judgment of the user. Only deviate from the median if absolutely certain.

**Step 4:** Multiply total energy consumed for water distribution by the appropriate GHG emissions factor for the community from Table WW.14.7, WW.14.8, or WW.14.9. See Appendix C, section BE.2 for guidance on choosing the appropriate factor.

For the total emissions for water consumption, sum the three elements of extraction, conveyance, treatment and distribution. This total should be reported separately from the wastewater total calculated in WW.15, and from the wastewater combustion, fugitive and process emissions calculated in Appendix F. Also, this total does not include emissions associated with electricity transmission and distribution losses. If you apply the method in Appendix C, Section BE.4 to other electricity use in your inventory, you should also apply it to this total.

**Equation WW.14.1 Total Energy-related Emissions as a Result of Water Consumption**  
**Annual CO<sub>2</sub>e emissions = Extraction + Conveyance + Treatment + Distribution**

**Extraction** = [(Source Percentage Groundwater x Population x per capita Use x Process Energy Intensity-Groundwater **Extraction**) x Unit Conversions+]

**Conveyance** = Σ (Source Percentage x Population x per capita Use x Process Energy Intensity-**Conveyance**)<sub>surface water only</sub>]x Energy Emissions Factor x Unit Conversions

**Treatment** = Σ (Source Percentage x Population x per capita Use x Process Energy Intensity-**Treatment**)<sub>groundwater, surface water only</sub> x Energy Emissions Factor x Unit Conversions

**Distribution** = Σ (Source Percentage x Population x per capita Use x Process Energy Intensity-**Distribution**)<sub>groundwater, surface water</sub> x Energy Emissions Factor x Unit Conversions

Where:

Description		Value
Annual CO <sub>2</sub> e emissions	= Total annual emissions from water extraction, conveyance, distribution and treatment	Result
Source Percentage	= Percentage of population drawing from either groundwater or surface water	User Input
Population	= Total population of the community	User Input
Per capita use	= Amount of water used by each member of the community on average. Includes all possible end uses for the water.	User Input
Water Processed	= Annual volume of water processed in an individual process (million gallons)	User Input
Process Energy Intensity	= Energy consumed per unit water processed (kWh/million gallons)	User Input
Energy Emissions Factors	= Standard electricity emissions factors from eGRID, or other verified source	User Input

State	per Capita Water Use Non-Self Supplied gal/d/capita	Percent Served by Self- Supply	Percent Served by Groundwater Supplies	Percent Served by Surface Water Supplies
Alabama	199	11	30.7	58.3
Alaska	177	35	22.2	42.8
Arizona	205	4	46.5	49.5
Arkansas	157	7	31.8	61.2
California	209	7	17.0	76.0
Colorado	198	6	11.1	82.9
Connecticut	180	24	12.0	64.0
Delaware	126	10	47.9	42.1
Florida	158	10	78.0	12.0
Georgia	158	18	17.7	64.3
Hawaii	218	6	89.7	4.3
Idaho	244	30	62.6	7.4
Illinois	147	9	21.7	69.3
Indiana	145	26	39.0	35.0
Iowa	163	18	64.3	17.7
Kansas	155	5	37.7	57.3
Kentucky	160	17	10.3	72.7
Louisiana	181	12	43.3	44.7
Maine	129	44	16.0	40.0
Maryland	146	17	11.7	71.3
Massachusetts	135	8	23.6	68.4
Michigan	158	29	16.2	54.8
Minnesota	134	22	54.0	24.0
Mississippi	156	19	72.4	8.6
Missouri	168	15	24.9	60.1
Montana	224	32	32.2	35.8
Nebraska	228	18	58.6	23.4
Nevada	303	8	18.4	73.6
New Hampshire	132	42	21.6	36.4
New Jersey	123	11	38.1	50.9
New Mexico	185	20	69.7	10.3
New York	145	10	17.9	72.1

<sup>45</sup> Adapted from Table 5, Public Supply Withdrawals, 2005, USGS Estimated Use of Water in the United States in 2005. See: <http://pubs.usgs.gov/circ/1344/pdf/c1344.pdf>

**Table WW.14.1 Public Water Supply Sources and per Capita Use - Continued**

State	per Capita Water Use Non-Self Supplied gal/d/capita	Percent Served by Self- Supply	Percent Served by Groundwater Supplies	Percent Served by Surface Water Supplies
North Carolina	144	26	12.5	61.5
North Dakota	126	16	39.9	44.1
Ohio	151	17	28.3	54.7
Oklahoma	199	8	16.2	75.8
Oregon	181	19	12.4	68.6
Pennsylvania	144	20	11.8	68.2
Rhode Island	121	8	12.4	79.6
South Carolina	217	30	16.3	53.7
South Dakota	150	14	56.7	29.3
Tennessee	168	9	33.1	57.9
Texas	207	10	25.5	64.5
Utah	245	3	55.6	41.4
Vermont	105	30	21.0	49.0
Virginia	167	22	6.7	71.3
Washington	184	14	46.8	39.2
West Virginia	135	23	15.2	61.8
Wisconsin	143	30	38.7	31.3
Wyoming	227	17	42.9	40.1
National Average <sup>46</sup>	171	14	28.4	57.6

<sup>46</sup> National average includes use in the states, the District of Columbia, Puerto Rico and the U.S. Virgin Islands.

**Table WW.14.2: Energy Intensities for Groundwater Extraction<sup>47</sup>**

	Groundwater Extraction (kWh/MG)	Water Table Depth (feet)
Low Value (default)	540	120
High Value	2270	500

**Table WW.14.3: Energy Intensities for Water Conveyance<sup>48</sup>**

	Local Water (kWh/MG)	Imported Water (kWh/MG)
Low Value	88	1900
Median Value	110	3000
High Value	330	5300

<sup>47</sup> From [Energy Down the Drain: The Hidden Costs of California's Water Supply](#), NRDC and The Pacific Institute, 2004, page 11

<sup>48</sup> Adapted from [Implications of Future Water Supply Sources for Energy Demands](#), WaterReuse Research Foundation, 2012. See: <http://www.pacinst.org/resources/wesim/report.pdf>, Table 4.2.



**Table WW.14.4: Energy Intensities for Water Treatment<sup>49</sup>**

	<1 MGD (kWh/MG)	1-5 MGD (kWh/MG)	5-20 MGD (kWh/MG)	>20 MGD (kWh/MG)
Low Value	620	300	180	120
Median Value	1500	750	560	210
High Value	2000	1300	1100	2000

**Table WW.14.5: Energy Intensities for Water Distribution<sup>50</sup>**

	Distribution Intensity (kWh/MG)
Low Value	360
Median Value	540
High Value	860

<sup>49</sup> Adapted from Implications of Future Water Supply Sources for Energy Demands, WaterReuse Research Foundation, 2012. See: <http://www.pacinst.org/resources/wesim/report.pdf>, Table 4.3.

<sup>50</sup> Adapted from Implications of Future Water Supply Sources for Energy Demands, WaterReuse Research Foundation, 2012. See: <http://www.pacinst.org/resources/wesim/report.pdf>, Table 4.8.

**Table WW.14.7 Utility-Specific Verified Electricity CO<sub>2</sub> Emission Factors (lbs CO<sub>2</sub>/MWh)**

	Year										
	2000 <sup>a</sup>	2001 <sup>a</sup>	2002 <sup>a</sup>	2003 <sup>a</sup>	2004 <sup>a</sup>	2005 <sup>a</sup>	2006 <sup>a</sup>	2007 <sup>a</sup>	2008 <sup>a</sup>	2009 <sup>a,b</sup>	2010 <sup>b</sup>
Anaheim Public Utilities						1,399.80	1,416.74	1,543.28			
Austin Energy						1,127.37	1,077.97	1,117.37			
City and County of San Francisco								76.28			
City of Palo Alto Public Utilities						320.94	39.02	426.82			
City of Vernon, Light and Power											775.83
Glendale Water & Power								1,065.00			
Los Angeles Department of Water & Power	1,407.44	1,403.39	1,348.48	1,360.07	1,360.60	1,303.58	1,238.52	1,227.89			
Modesto Irrigation District, Retail Power										1,036.17	942.99
Modesto Irrigation District, Wholesale Power										2,048.09	2,026.12
Newmont Nevada Energy Investment											2,055.79
Pacific Gas & Electric Company					566.20	489.16	455.81	635.67		575.38	444.64
PacifiCorp					1,811.00	1,812.22	1,747.30	1,775.28			
Pasadena Water & Power							1,409.65	1,664.14			
Platte River Power Authority						1,970.93	1,955.66	1,847.88			
Riverside Public Utilities						1,333.45	1,346.15	1,325.65			
Roseville Electric							565.52	793.80			
Sacramento Municipal Utility District					769.00	616.07	555.26	714.31			526.47
Salt River Project							1,546.28	1,469.90			
San Diego Gas & Electric					613.75	546.46	780.79	806.27	739.05	720.49	
Seattle City Light								17.77			
Sierra Pacific Resources								1,442.78			
Southern California Edison					678.88	665.72	641.26	630.89			

*Data Source Notes:*

<sup>a</sup>Data from the California Climate Action Registry Power/Utility Protocol public reports, <http://www.climateregistry.org/CARROT/public/reports.aspx>

<sup>b</sup>Data from the Climate Registry Electric Power Sector Protocol public reports, <http://www.climateregistry.org/carrot/public/reports.aspx>

**Table WW.14.8 California Grid Average Electricity Emission Factors (1990-2007) (lbs/MWh)**

Year	CO <sub>2</sub>	CH <sub>4</sub>	N <sub>2</sub> O	CO <sub>2</sub> e
1990	1031.14	0.040	0.014	1036.19
1991	994.03	0.037	0.013	998.72
1992	984.42	0.040	0.012	988.87
1993	1007.26	0.037	0.013	1011.95
1994	1071.19	0.040	0.013	1075.94
1995	929.77	0.031	0.012	934.03
1996	827.65	0.029	0.011	831.57
1997	874.96	0.029	0.011	878.88
1998	941.54	0.029	0.011	945.46
1999	917.60	0.031	0.011	921.56
2000	829.50	0.029	0.009	832.82
2001	1009.75	0.033	0.011	1013.75
2002	865.28	0.031	0.010	868.94
2003	888.41	0.031	0.011	892.37
2004	958.49	0.029	0.011	962.41
2005	948.28	0.030	0.011	952.22
2006	889.75	0.031	0.009	893.11
2007	919.64	0.029	0.010	923.26

*Sources: Calculated from total in-state and imported electricity emissions divided by total use in MWh. Emissions from California Air Resources Board, Greenhouse Gas Inventory, 1990 – 2004 (November 17, 2007 version), available on line. CO<sub>2</sub>e calculated using current 100-year Global Warming Potentials (GWPs) from US EPA. (GWP<sub>CO2</sub> = 1, GW<sub>CH4</sub> = 21, GWP<sub>N2O</sub> = 310).*

**Table WW.14.9 eGRID Sub-region 2009 CO<sub>2</sub>e Emission Rates**

Region	eGRID Sub-region Acronym	eGRID Sub-region Name	Annual CO <sub>2</sub> Equivalent Electricity Emission Rate (lb/MWh)
Alaska	AKGD	ASCC Alaska Grid	1,283.82
Alaska	AKMS	ASCC Miscellaneous	523.05
Eastern	FRCC	FRCC All	1,181.63
Eastern	MROE	MRO East	1,600.54
Eastern	MROW	MRO West	1,637.82
Eastern	NYLI	NPCC Long Island	1,353.86
Eastern	NEWE	NPCC New England	734.29
Eastern	NYCW	NPCC NYC/Westchester	612.04
Eastern	NYUP	NPCC Upstate NY	500.35
Eastern	RFCE	RFC East	952.63
Eastern	RFCM	RFC Michigan	1,668.76
Eastern	RFCW	RFC West	1,528.76
Eastern	SRMW	SERC Midwest	1,759.15
Eastern	SRMV	SERC Mississippi Valley	1,006.12
Eastern	SRSO	SERC South	1,332.59
Eastern	SRTV	SERC Tennessee Valley	1,364.92
Eastern	SRVC	SERC Virginia/Carolina	1,041.73
Eastern	SPNO	SPP North	1,825.15
Eastern	SPSO	SPP South	1,606.26
ERCOT	ERCT	ERCOT All	1,186.14
Hawaii	HIMS	HICC Miscellaneous	1,357.46
Hawaii	HIOA	HICC Oahu	1,602.30
Western	CAMX	WECC California	661.20
Western	NWPP	WECC Northwest	823.40
Western	RMPA	WECC Rockies	1,833.41
Western	AZNM	WECC Southwest	1,196.58

Source: eGRID2010 Version 1.0 Sub-region data (Year 2009 Data), <http://www.epa.gov/cleanenergy/energy-resources/eGRID/index.html>

## **WW.15 Energy-related Emissions Associated with Wastewater Collection and Treatment**

### **Introduction**

The energy demands for collection and treatment of wastewater can be on par with the energy demands for water conveyance, treatment and distribution for many communities. There are many communities where the wastewater emissions may be dwarfed by emission from water conveyance due to extensive pumping requirements over long distances. Conversely, other communities may have significant energy demands from wastewater treatment if those facilities are required to meet stringent effluent discharge requirements and/or they choose not to capitalize on renewable energy opportunities associated with wastewater treatment. Thus, there is no nexus between the energy requirements of water and wastewater management.

The methods described in this section account for the final stages in the water cycle; those associated with wastewater treatment. As with the methods in Appendix F, no consideration is given for renewable energy opportunities within the treatment process. As in method WW.14, methods are implemented from a water cycle perspective. Therefore, double counting with GHG emission sources accounted for in other sectors may be likely. For example, stationary energy consumption at wastewater treatment facilities within a community's boundary may be at risk for double counting. For this reason, GHG emissions from wastewater collection and treatment should not be summed with GHG emissions from other direct sources (i.e. stationary energy consumption).

Several processes exist which, when combined, provide for the GHG emissions of a community's wastewater management strategy. Figure WW.15.1 highlights the different energy consuming processes involved in the collection and treatment of wastewater. The energy intensity of each of these highlighted processes and the volume of wastewater passing through each will need to be known in order to accurately inventory emissions associated with wastewater management. The degree to which each of the processes used for collection and treatment of your community's wastewater is identified, and the energy intensity of each of those processes is known, will define the accuracy of the methods for determining the GHG emissions from wastewater collection and treatment.

Communities may employ a mix of strategies to manage their wastewater needs. It is more common for rural communities, for example, to employ on-site treatment systems. However, these may be found in some urban environments as well, and some rural communities may also be served by a centralized system. The EPA maintains a database (The Clean Watershed Needs Survey - CWNS)<sup>51</sup> that documents the major processes employed, and through this database, state-by-state information is available and reported here. Although the energy demand for on-

---

<sup>51</sup> <http://water.epa.gov/scitech/datait/databases/cwns/index.cfm>

site systems is negligible, it is important to identify the percentage in the community that uses these systems so that only those populations that employ the other processes with significant energy demands be considered.


The CWNS database also can be used to determine the percent of the population that employs various degrees of centralized treatment. Generally, as the treatment needs become more stringent, the energy demand increases<sup>52</sup>. The energy demand for each major process modality should be considered and weighted against the population served by that kind of process.

The per capita use of water is rarely equal to the per capita generation of wastewater. Not all water use ends up in the wastewater collection system; waters needed for irrigation and agricultural use are important examples. Conversely, wastewater collection systems in some states may be “combined” systems that include stormwater drainage. Additionally, there may be infiltration in some collection systems. Thus, a table is presented to report default values for the per capita generation of wastewater for each state, again based on the EPA’s CWNS database.

---

<sup>52</sup> A possible exception to this is the use of some facilities to achieve combined nitrification/denitrification (NDN). Some facilities are reporting *lower* energy demand for NDN than for conventional secondary treatment. Nevertheless, the energy needs for this level of advanced treatment are assumed to be consistent with those described in the CWNS for Advanced Treatment II technologies, which may include other energy intensive processes such as UV disinfection, and microfiltration or reverse osmosis..

**Figure WW.15.1 Energy Consuming Processes in the Collection and Treatment of Wastewater<sup>53</sup>**



Energy consumption and resulting GHG emissions should be accounted for in each wastewater process highlighted from Figure WW.15. The end-use phase is excluded from analysis. End Use consists of the electricity or fossil fuels used at community residences, commercial buildings or industrial facilities for heating cooling, and final dispersal of water (when these require additional power inputs). End Use emissions will already be contained in calculations done in Appendix C: Built Environment Emission Activities and Sources. Emissions from water supply/conveyance, treatment and distribution *might* be accounted for in Appendix C (or maybe just in part) if your water facilities are located within your community, however, in most cases, these facilities are spread out across numerous jurisdictions.

The wastewater system components in each process in your wastewater system that should be accounted for in this section may include:

- Wastewater Collection:
  - Pumps used to move wastewater to a treatment facility. Much wastewater collection is gravity fed, however lift-station pumps are used when elevation gain is needed.

<sup>53</sup> Klein, Gary, Ricardo Amon, Shahid Chaudhry, Loraine White, et al. California's Water-Energy Relationship: Final Staff Report. Nov. 2005. California Energy Commission. Available at: <<http://www.energy.ca.gov/2005publications/CEC-700-2005-011/CEC-700-2005-011-SF.PDF>>.

- Wastewater Treatment:
  - Pumps within the wastewater treatment plant, plus specific treatment equipment that may include aeration blowers or mixers, pressurized filtration, mechanical dewatering and thickening, heating, digestion equipment.
- Wastewater Discharge:
  - Pumps used to convey treated wastewater back to a receiving body of water or underground injection site. This energy demand may be small and/or may be difficult to consider separately from the demands for treatment if the discharge pumping occurs at the facility.

## Uncertainties and Limitations

Like WW.14, for users without site-specific information, this method combines state level usage with nation-wide energy intensities and regional energy to GHG emission conversions, each with different vintages and different degrees of reliability. Such users should be cautioned against using WW.14 or WW.15 to meet regulatory requirements such as those in federal or state mandatory reporting rules or, in California, CEQA. Although Lead Agencies in CEQA have the discretion to choose their preferred emissions estimation method, they must be able to justify why that method is the best for their project. Thus, tools designed to meet regulatory requirements such as EPA's Energy Star Portfolio Manager or CalEEMod<sup>54</sup> for CEQA may be more appropriate for that purpose. Other tools that are more comprehensive such as WESim<sup>55</sup> may be more suitable as well. The best results are from site-specific values that are better than any model regardless of the source.

The results from the 2008 CWNS reported here differ from accounts reported elsewhere based on the 2004 survey such as in the annual EPA National GHG Inventory. The Inventory, for example, suggests that septic systems account for as much as 20% of the nation's treatment for wastewater, lagoons 10% and nitrification/denitrification (NDN) only served 2.4 million people<sup>56</sup>. The results reported in Table WW.15.1 based on the 2008 CWNS instead state that nationwide, septic systems account for 11% of treatment, lagoons 1% and NDN serves a much higher population. Although it is certain that the NDN population is greater than that referenced in the Inventory, the CWNS has other inconsistencies that make any conclusions drawn from it questionable. For example, the CWNS for several states only accounts for roughly 60% nearly half the population and there is a shortfall nationwide of roughly 40 million people between the census estimate for 2008 and the population accounted for in the CWNS. Additionally, it's not clear how accurate the process designations are or if they have been updated with each new survey. EPA has plans to improve the reliability of the database for its 2012 report.

---

<sup>54</sup> CalEEMod was developed by the California Air Pollution Control Officers Association for purposes of estimating impacts of projects under CEQA and thus is valid only for California users. See: <http://caleemod.com/>

<sup>55</sup> <http://pacinst.org/resources/wesim/index.htm>

<sup>56</sup> <http://www.epa.gov/climatechange/Downloads/ghgemissions/US-GHG-Inventory-2012-Chapter-8-Waste.pdf>, see page 8-10.



## **Recommended Approach**

The recommended approach for calculating GHG emissions for wastewater collection and treatment, utilizes community-specific energy consumed per unit of wastewater for each process of the wastewater system. If you are not able to obtain community-specific energy intensities, use default factors as outlined below.

## **Method WW.15 Calculation of Upstream Emissions Associated with Wastewater Collection and Treatment**

### **WW.15 Data Needs**

- Wastewater Collection:
  - Proportion of centralized treatment (all treatment modalities except on-site)
  - Population
  - Wastewater generation per capita
  - Default factor for wastewater collection energy intensity
  - Community specific energy to GHG emissions

The method considers only the energy intensity of centralized treatment since on-site systems require no collection energy expenditure.

- Wastewater Treatment:
  - Percentage of on-site treatment systems and split between the centralized system treatment modalities
  - Population
  - Wastewater generation per capita
  - Default factors for each wastewater treatment modality
  - Community specific energy to GHG emissions
  - (See Box WW.15 in the appendix of this document for an example calculation.)

The method considers only the energy intensity of centralized wastewater treatment systems since the energy intensities for on-site septic tanks is negligible. Septic tanks are assumed to comprise most of the on-site systems.

Wastewater discharge energy intensities are assumed to be negligible. Typically, flow exits the facility by gravity into the receiving watersheds. Additionally, for those facilities that do require discharge pumping, often that pumping occurs within the treatment facility and that electricity use is difficult to separate from the treatment plant as a whole.

### **WW.15 Calculation Method**

The method presented considers each wastewater element of the water cycle individually and sums the conveyance, treatment and distribution emissions at the end. Note the method assumes on-site treatment has negligible emissions.


Special energy intensities are reported for California because of the unique challenges that accompany that state's water needs. For the wastewater elements, apply 2500 kWh/MG to the

population served by centralized systems for California; exclude the on-site systems (e.g., septic tanks) for this analysis.

Figure WW.15.2 can guide the user through the steps required to calculate electricity use from the management of wastewater by a community.

In these methods, if a table or method calls for a size in units of million gallons (MG), that metric can be obtained by multiplying the per capita generation by the population and dividing by one million. Use this approach only if you are certain what type of treatment process is being used and if the population (from all communities, not just yours) served by that process is known. Otherwise, refer to the energy intensities for the default treatment plant sizes.

**FIGURE WW.15.2: Decision Tree for Reporting Electricity Use from Wastewater Management within your Community**



## **WASTEWATER COLLECTION**

**Step 1:** Obtain the proportion of centralized treatment. Refer to Table WW.15.1 for a state-by-state distribution if the community specific distribution is not known or obtainable.

**Step 2:** Multiply the total population of the community by the fraction receiving centralized treatment and the state's per capita wastewater generation, found in table WW.15.1 to get the actual volume sent to the collection system.

**Step 3:** Multiply the volume sent to the collection system for the community by the energy intensity per unit of wastewater collected. Refer to Table WW.15.2 for wastewater collection default energy intensities if the community specific value is not known. The collection energy intensity for on-site systems is assumed to be negligible. Variability in the energy requirements for wastewater collection is dependent upon local geography and pump efficiency, with flatter topography associated with the lower end of the range<sup>57</sup>. Only deviate from the median value if certain that your terrain and pumping is at either end of the range.

**Step 4:** Multiply total energy consumed for wastewater collection by the appropriate GHG emissions factor for the community from Table WW.14.7, WW.14.8, or WW.14.9. See Appendix C, section BE.2 for guidance on choosing the appropriate factor.

## **WASTEWATER TREATMENT**

**Step 1:** Obtain the proportions of on-site and centralized treatment. Refer to Table WW.15.1 for a state-by-state distribution if the community specific distribution is not known or obtainable.

**Step 2:** Further break down the proportions of the flow sent to centralized systems by the percentages for each system type. Use the defaults for each state found in Table WW.15.2 if community specific distributions are not known or obtainable. Make sure you have accounted for all treatment types present. If you know a particular type is NOT present, you may recalculate the percentages in Table WW.15.2 to reflect that.

**Step 3:** Multiply the percentages of the total population of the community serviced by each treatment modality by the state's per capita use, found in table WW.15.2 to get the actual volume. Note that trickling filters and rotating biological contactors are considered to be attached growth processes in this table. If the size of the treatment process is not known or cannot be determined, use the default values in Table WW.15.3.

---

<sup>57</sup> <http://pacinst.org/resources/wesim/index.htm>, see Table 4.10 on page 35.

**Step 4:** Multiply the volume sent to each treatment modality by the appropriate process energy consumed per unit of treated wastewater to calculate total energy consumed. Refer to Table WW.15.3 for treatment default energy intensities if the community specific value is not known. Note that trickling filters and rotating biological contactors are considered to be attached growth processes in this table.

**Step 5:** Multiply total energy consumed for wastewater treatment by the appropriate GHG emissions factor for the community from Table WW.14.7, WW.14.8, or WW.14.9. See Appendix C, section BE.2 for guidance on choosing the appropriate factor.

For the total emissions for wastewater collection and treatment, sum the two elements of collection and treatment. This total should be reported separately from the water total calculated in WW.14, and from the wastewater combustion and process emissions calculated in Appendix F. Also, this total does not include emissions associated with electricity transmission and distribution losses. If you apply the method in Appendix C, Section BE.4 to other electricity use in your inventory, you should also apply it to this total.

**Equation WW.15.1 Total Energy-related Emissions as a Result of Wastewater Collection and Treatment**

**Annual CO<sub>2</sub>e emissions = Collection + Treatment + Distribution**

**Collection** = [(Percentage Using Centralized Treatment x Population x per capita Use x Process Energy Intensity- **Collection**) x Energy Emissions Factor x Unit Conversions]

**Treatment** =  $\sum$  (Modality Percentage x Population x per capita Use x Modality Specific Process Energy Intensity-**Treatment**)<sub>all centralized treatment modalities</sub> x Energy Emissions Factor x Unit Conversions

**Distribution** = Assumed to be negligible

Where:

Description		Value
Annual CO <sub>2</sub> e emissions	= Total annual emissions from wastewater collection and treatment	Result
Percentage Using Centralized Treatment	= Percentage of wastewater flow not sent to on-site systems like septic tanks	User Input
Population	= Total population of the community, regardless of treatment modality	User Input
Per Capita Use	= Total contributions of wastewater from all sources divided by total population	User Input
Collection Process Energy Intensity	= Energy consumed per unit wastewater processed in the centralized system (kWh/million gallons)	User Input
Modality Specific Process Energy Intensity	= Energy consumed per unit wastewater processed in each treatment modality (kWh/million gallons)	User Input
Energy Emissions Factors	= Standard electricity emissions factors from eGRID, or other verified source	User Input

**Table WW.15.1 Wastewater Decentralized Septic and Centralized Treatment Modalities Sources and per Capita Use<sup>58</sup>**

State	Decentralized Septic	Centralized Treatment				per Capita Generation gal/day/capita
		Lagoon	Attached Growth	Activated Sludge	NDN	
Alabama	12%	0%	6%	68%	13%	177
Alaska	29%	0%	0%	71%	0%	202
Arizona	5%	2%	3%	66%	24%	86
Arkansas	3%	4%	3%	88%	1%	166
California	3%	1%	4%	86%	6%	100
Colorado	6%	3%	6%	78%	6%	125
Connecticut	38%	0%	1%	38%	23%	188
Delaware	0%	41%	0%	59%	0%	138
Florida	30%	0%	1%	56%	12%	119
Georgia	1%	0%	1%	76%	22%	145
Hawaii	0%	0%	23%	77%	0%	169
Idaho	2%	17%	12%	54%	15%	123
Illinois	2%	1%	1%	95%	1%	194
Indiana	17%	4%	12%	58%	10%	186
Iowa	1%	3%	12%	73%	11%	147
Kansas	16%	10%	9%	44%	21%	139
Kentucky	5%	0%	13%	82%	1%	149
Louisiana	3%	0%	18%	78%	0%	150
Maine	46%	1%	2%	47%	4%	226
Maryland	23%	0%	0%	27%	49%	118
Massachusetts	18%	0%	1%	43%	37%	165
Michigan	4%	2%	3%	88%	3%	186
Minnesota	22%	1%	0%	34%	42%	129
Mississippi	20%	13%	3%	55%	9%	138
Missouri	26%	3%	25%	42%	3%	187
Montana	7%	3%	3%	72%	15%	151
Nebraska	2%	0%	29%	53%	15%	146
Nevada	1%	0%	23%	38%	38%	83
New Hampshire	4%	0%	0%	96%	0%	176
New Jersey	1%	1%	8%	85%	5%	150
New Mexico	9%	0%	0%	91%	0%	75

<sup>58</sup> Adapted from <http://water.epa.gov/scitech/datait/databases/cwns/index.cfm>, EPA, 2008.

Table WW.15.1 Continued Wastewater Decentralized Septic and Centralized Treatment Modalities Sources and per Capita Use

State	Decentralized Septic	Centralized Treatment				per Capita Generation gal/day/capita
		Lagoon	Attached Growth	Activated Sludge	NDN	
New York	17%	0%	1%	64%	17%	178
North Carolina	7%	0%	4%	72%	17%	155
North Dakota	7%	0%	0%	93%	0%	94
Ohio	13%	0%	7%	72%	8%	205
Oklahoma	0%	9%	13%	77%	1%	136
Oregon	1%	1%	3%	60%	34%	118
Pennsylvania	2%	0%	3%	91%	4%	140
Rhode Island	30%	0%	2%	68%	0%	183
South Carolina	16%	1%	0%	81%	2%	218
South Dakota	15%	0%	74%	11%	0%	112
Tennessee	7%	3%	7%	83%	0%	184
Texas	3%	1%	0%	88%	8%	114
Utah	2%	10%	36%	41%	11%	129
Vermont	27%	1%	5%	66%	0%	142
Virginia	8%	0%	1%	53%	38%	121
Washington	16%	1%	1%	66%	16%	161
West Virginia	39%	0%	1%	60%	0%	185
Wisconsin	1%	2%	4%	85%	8%	153
Wyoming	0%	29%	22%	48%	0%	107
Total Population (50 states + DC + Territories)	11%	1%	5%	72%	11%	144



Table WW.15.2 Range of Energy Intensities for Wastewater Collection <sup>59</sup>	
	Collection Energy Intensity (kWh/MG)
Low Value	140
Median Value	280
High Value	440

Table WW.15.3 Range of Energy Intensities for Wastewater Treatment				
Treatment Modality	Default Size			
	Size: (kWh/MG)	1-5 MGD (kWh/MG)	5-20 MGD (kWh/MG)	20-50 MGD (kWh/MG)
Conventional Aerobic <sup>60</sup>	2300	2000	1600	1400
Lagoon <sup>61</sup>	Use 1150 for all sizes			
Attached Growth <sup>62</sup>	1500	1400	1200	960
NDN <sup>63</sup>	3300	3000	2400	1800

<sup>59</sup> <http://pacinst.org/resources/wesim/index.htm>, see Table 4.10 on page 35.

<sup>60</sup> Ibid. See Table 4.11 on page 36, median values used.

<sup>61</sup> Energy Index Development for Benchmarking Water and Wastewater Utilities, AWWA Research Foundation, et al., page 141. 2007

<sup>62</sup> <http://pacinst.org/resources/wesim/index.htm>, see Table 4.11 on page 36., low values used.

<sup>63</sup> Ibid., see Table 4.13 on page 36., median values used.

## Example Calculations for Wastewater and Water Activities and Sources Emissions

Box WW.1.a below gives an example of how to calculate the CH<sub>4</sub> emission from devices designed to combust digester gas using the methodology consistent with the EPA and California Air Resources Board mandatory reporting rules if the CH<sub>4</sub> fraction of the gas is known.

<b>Box WW.1.a</b>		
<b>Example Calculation of CH<sub>4</sub> Emissions from the Incomplete Combustion of Anaerobic Digester Gas with Fraction of CH<sub>4</sub> Known</b>		
A wastewater facility generates 1,000,000 ft <sup>3</sup> per day of digester gas containing 65% CH <sub>4</sub> . The BTU content of the digester gas is not available. Based on this scenario the CH <sub>4</sub> emissions from the incomplete combustion of digester biogas can be calculated as follows		
Description		Value
CH <sub>4</sub> emissions	= Total CH <sub>4</sub> emitted by incomplete combustion (mtCO <sub>2</sub> e)	Result
Digester gas	= Measured standard cubic feet of digester gas produced per day (std ft <sup>3</sup> /day)	1,000,000
fCH <sub>4</sub>	= Fraction of CH <sub>4</sub> in biogas	0.65
BTU <sub>CH4</sub>	= Default BTU content of CH <sub>4</sub> , higher BTU content (BTU/ft <sup>3</sup> )	1028
10 <sup>-6</sup>	= Conversion from BTU to 1 MMBTU	10 <sup>-6</sup>
EF <sub>CH4</sub>	= CH <sub>4</sub> emission factor (kg CH <sub>4</sub> /MMBTU)	3.2 X 10 <sup>-3</sup> kg CH <sub>4</sub> per MMBTU
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH4</sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> e	GWP <sup>64</sup>
Sample Calculation:		
$\text{Annual CH}_4 \text{ emissions} = (1,000,000 \times 0.65 \times 1028 \times 10^{-6} \times (3.2 \times 10^{-3}) \times 365.25 \times 10^{-3}) \times 21$ $= 18 \text{ mtCO}_2\text{e}$		

- If a facility's BTU content is known, it's acceptable for use. *Equation WW.1.b* should be utilized; this entails conducting *Equation WW.1.a* with the exception of replacing the fraction of CH<sub>4</sub> in biogas (fCH<sub>4</sub>) and the default BTU content of CH<sub>4</sub> (BTU<sub>CH4</sub>) with the facility's specific values (BTU<sub>digester gas</sub>).

<sup>64</sup> See Appendix GWP for value.

- If only the population served is known, it's acceptable for use. *Equation WW.1.(alt)* should be utilized; this entails conduction *Equation WW.1.a* with the exception of replacing the measured standard cubic feet of digester gas produced per day (Digester gas), from *Equation WW.1.a*, with the population served by anaerobic digester (P) multiplied by the measured standard cubic feet of digester gas produced per person per day (1.0).

Box WW.3 below gives an example of how to calculate biogenic CO<sub>2</sub> emissions from the combustion of digester gas.

<b>Box WW.3</b>		
<b>Example Calculation of Biogenic CO<sub>2</sub> Emissions from Digester Gas Combustion</b>		
A wastewater facility generates 1,000,000 ft <sup>3</sup> per day of digester gas. The BTU content of the gas is not available. Based on this scenario the biogenic CO <sub>2</sub> emissions from the combustion of digester biogas can be calculated as follows:		
Description		Value
CO <sub>2</sub> emissions	= Total annual biogenic CO <sub>2</sub> emitted by combustion of biogas (mtCO <sub>2</sub> e)	Result
Description		Value
Digester gas	= Standard cubic feet of digester gas produced per day (std ft <sup>3</sup> /day)	1,000,000
BTU <sub>CO2</sub>	= BTU content of biogas (MMBTU/scf)	0.000841
EF <sub>CO2</sub>	= Emission factor for CO <sub>2</sub> (kg CO <sub>2</sub> /MMBTU)	52.07
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion factor kg to mt	10 <sup>-3</sup>
Sample Calculation		
$\text{Annual CO}_2 \text{ emissions} = \text{Digester gas} * \text{BTU}_{\text{CO}_2} * \text{EF}_{\text{CO}_2} * 365.25 * 10^{-3}$ $= 1000000 * 0.000841 * 52.07 * 365.25 * 10^{-3}$ $= 15995 \text{ mtCO}_2$		

Box WW.4 below gives an example of how to calculate the CH<sub>4</sub> emissions from the combustion of WWTP residuals on a wet weight basis.

<b>Box WW.4</b>		
<b>Example Calculation of CH<sub>4</sub> Emissions from the Combustion of WWTP Residuals on a Wet Weight Basis</b>		
A wastewater facility sends out to incineration 2,000 wet tons per day of residuals. Based on this scenario the CH <sub>4</sub> emissions from the combustion of WWTP residuals on a wet weight basis can be calculated as follows		
Description		Value
CH <sub>4</sub> emissions	= Total CH <sub>4</sub> emitted by residuals combustion (mtCO <sub>2</sub> e)	Result
Wet Weight	= Wet weight of sludges or biosolids incinerated (ton/day)	User Input
EF <sub>CH<sub>4</sub></sub>	= CH <sub>4</sub> emission factor (g CH <sub>4</sub> /ton)	9.7 g CH <sub>4</sub> per ton
365.25	= Conversion factor (day/year)	365.25
10 <sup>-6</sup>	= Conversion from g to mt	10 <sup>-6</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> e	GWP <sup>65</sup>
Sample Calculation:		
$\text{Annual CH}_4 \text{ emissions} = (2,000 \times 9.7 \times 365.25 \times 10^{-6}) \times 21$ $= 163 \text{ mtCO}_2\text{e}$		

- Equation WW.5 should be utilized to calculate the N<sub>2</sub>O emissions from the combustion of WWTP residuals on a wet weight basis. This entails conducting Equation WW.4 with the exception of replacing the CH<sub>4</sub> emission factor (EF<sub>CH<sub>4</sub></sub>) with the N<sub>2</sub>O emission factor (EF<sub>N<sub>2</sub>O</sub>) and replacing the GWP of CH<sub>4</sub> (21) with GWP of N<sub>2</sub>O (310).

<sup>65</sup> See Appendix GWP for value.

Box WW.6.(alt) below gives an example of how to calculate emissions from a lagoon facility when the only data obtainable is population served by lagoon

<b>Box WW.6(alt)</b>		
<b>Example Calculation of CH<sub>4</sub> emissions from a Lagoon when only Population Served by Lagoon is Known</b>		
A lagoon collects sewage from a nearby town. The population served by this lagoon is 10,000. They have an industrial factory that discharges more than 25,000 gpd of wastewater. Based upon this scenario, the inputs are as follows		
Description		Value
Annual CH <sub>4</sub> emissions	= Total annual CH <sub>4</sub> emitted by lagoon (mtCO <sub>2</sub> e)	Result
P	= Population served by lagoon	10,000
Description		Value
<i>F<sub>ind-com</sub></i>	= Factor for industrial and commercial discharge waste	1.25
BOD <sub>5</sub> load	= Amount of BOD <sub>5</sub> treated per day (kg BOD <sub>5</sub> /person/day)	0.090
F <sub>p</sub>	= Fraction of BOD <sub>5</sub> removed in primary treatment	0.325
Bo	= Maximum CH <sub>4</sub> producing capacity for domestic wastewater (kg CH <sub>4</sub> /BOD <sub>5</sub> removed)	0.6
MCF <sub>a</sub>	= CH <sub>4</sub> correction factor for anaerobic systems	0.8
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> e	GWP <sup>66</sup>
Sample Calculation:		
$\text{Annual CH}_4 \text{ emissions} = ((10000 \times 1.25) \times 0.090 \times (1-0.325) \times 0.6 \times 0.8 \times 365.25 \times 10^{-3}) \times 21$ $= 3062.1 \text{ mtCO}_2\text{e}$		

- If the BOD<sub>5</sub> load is known, it's acceptable for use. Equation WW.6 should be utilized; this entails conduction Equation WW.6.(alt) with the exception of replacing the population served by lagoon (P), the factor for industrial and commercial discharge waste (*F<sub>ind-com</sub>*), and the amount of BOD<sub>5</sub> treated per day (BOD<sub>5</sub> load) with the known amount of BOD<sub>5</sub> load treated per day (BOD<sub>5</sub> load).

<sup>66</sup> See Appendix GWP for value.

Box WW.8 below gives an example of how to calculate N<sub>2</sub>O emissions from a WWTP without nitrification/denitrification.

<b>Box WW.8</b>		
<b>Example Calculation of N<sub>2</sub>O Process Emissions from WWTP without Nitrification or Denitrification</b>		
A WWTP serves a population of 10,000 people. This WWTP does not use nitrification/denitrification and receives a significant amount of industrial waste demonstrated to have high nitrogen. Based upon this scenario, the inputs are as follows		
Description		Value
N <sub>2</sub> O emissions	= Total annual N <sub>2</sub> O emitted by WWTP processes (mtCO <sub>2</sub> e)	Result
P	= Population served by WWTP	10,000
<i>F<sub>ind-com</sub></i>	= Factor for industrial or commercial discharge	1.25
EF <sub>w/o nit/denit</sub>	= Emission factor for a WWTP without nitrification/denitrification	3.2
Person equivalent	= 100 gallons per day	
10 <sup>-6</sup>	= Conversion from g to mt (mt/g)	10 <sup>-6</sup>
GWP <sub>N<sub>2</sub>O</sub>	= Global Warming Potential	GWP <sup>67</sup>
Sample Calculation:		
Annual N <sub>2</sub> O emissions = ((10000 × 1.25) × 3.2 × 10 <sup>-6</sup> ) × 310		
= 12.4 mtCO <sub>2</sub> e		

- WWTPs with nitrification or denitrification should utilize *Equation WW.7*; this entails conducting *Equation WW.8* with the exception of replacing the emission factor for a WWTP without nitrification/denitrification (EF<sub>w/o nit/denit</sub>=3.2) with the emission factor for a WWTP with nitrification/denitrification (EF<sub>nit/denit</sub>=7).

<sup>67</sup> See Appendix GWP for value.

Box WW.9 below gives an example of how to calculate CO<sub>2</sub> emissions from methanol use.

<b>Box WW.9</b>		
<b>Example Calculation of CO<sub>2</sub> Emissions from Methanol Use</b>		
A WWTP uses 10 mt/day of methanol for nitrogen removal and employs anaerobic digestion. Based upon this scenario, the inputs are as follows:		
Description		Value
Annual CO <sub>2</sub> emissions	= Total annual CO <sub>2</sub> emitted (mtCO <sub>2</sub> e)	Result
Methanol load	= Amount of neat chemical used per day (mt CH <sub>3</sub> OH/day)	10
F	= Factor to be applied based on WWTP's sludge treatment type:	0.80
	<ul style="list-style-type: none"> <li>• Raw Solids Disposal      80%</li> <li>• <b>Anaerobic Digestion</b>      <b>60%</b></li> <li>• Solids Combustion      100%</li> </ul>	
44.01/32.04	= Molecular weight ratio of 44.01 (for CO <sub>2</sub> ) to 32.04 (for CH <sub>3</sub> OH)	1.37
365.25	= Conversion factor from days to year	365.25
Sample Calculation:		
Annual CO <sub>2</sub> e emissions assuming anaerobic digestion = (10 x 0.80 x 1.37 x 365.25)		
= 4,000 mtCO <sub>2</sub> e		

Box WW.11(alt) below gives an example of how to calculate emission from a septic system when the only data the user can obtain is the population served by septic system.

<b>Box WW.11(alt)</b>		
<b>Example Calculation of CH<sub>4</sub> emissions from a Septic System when only Population Served by System is Known</b>		
The residential areas of a small town are served by septic systems. The population of the town is 2,000 people and thus considered rural. Based upon this scenario, the inputs are as follows:		
Description		Value
CH <sub>4</sub> emissions	= Total CH <sub>4</sub> emitted by septic systems (mtCO <sub>2</sub> e)	Result
P	= Population served by septic systems	2000 * 0.90
BOD <sub>5</sub> load	= Amount of BOD <sub>5</sub> treated per day (kg BOD <sub>5</sub> /person/day)	0.090
Bo	= Maximum CH <sub>4</sub> producing capacity for domestic wastewater (kg CH <sub>4</sub> /BOD <sub>5</sub> removed)	0.6
MCF <sub>5</sub>	= CH <sub>4</sub> correction factor for septic systems	0.22
GWP <sub>CH<sub>4</sub></sub>	= Global Warming Potential; conversion from mt of CH <sub>4</sub> into mt of CO <sub>2</sub> e	21 <sup>68</sup>
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
Sample Calculation:		
<i>P = total population * default rural</i>		
<i>P = 2000*0.90</i>		
<i>P = 1800</i>		
<i>Annual CH<sub>4</sub> emissions = (P x BOD<sub>5</sub> load x Bo x MCFs x 365.25 x 10<sup>-3</sup>) x GWP</i>		
<i>= (1800 × 0.090 × 0.6 × 0.22 × 365.25 × 10<sup>-3</sup>) × 21</i>		
<i>= 180 mtCO<sub>2</sub>e</i>		

- If the BOD<sub>5</sub> load is known, it's acceptable for use. *Equation WW.11.a* should be utilized; this entails conduction *Equation WW.11.b* with the exception of replacing the population served by septic system (P) and the amount of BOD<sub>5</sub> treated per day (BOD<sub>5</sub> load) with the known amount of BOD<sub>5</sub> treated per day (BOD<sub>5</sub>).

<sup>68</sup> See Appendix GWP for value.



Box WW.12(alt) below gives an example of how to calculate N<sub>2</sub>O emissions from the effluent conversion from a WWTP.

<b>Box WW.12(alt)</b>		
<b>Example Calculation of N<sub>2</sub>O Emissions from Effluent Conversion</b>		
A WWTP serves a population of 10,000 people. This WWTP also employs nitrification/denitrification in its treatment process; however, the amount of nitrogen in the effluent discharge is unknown. The community has a significant industrial base. Based upon this scenario, the inputs are as follows:		
Description		Value
N <sub>2</sub> O emissions	= Total annual N <sub>2</sub> O emitted by effluent conversion of discharged nitrogen (mtCO <sub>2</sub> e)	Result
P	= Population served by WWTP	10,000
<i>F<sub>ind-com</sub></i>	= Factor for industrial or commercial discharge	1.25
Total N-Load	= Average total nitrogen per day (kg N/day)	0.026
N uptake	= Nitrogen uptake for cell growth (kg N/kg BOD <sub>5</sub> )	0.05
BOD <sub>5</sub>	= Amount of BOD <sub>5</sub> produced per person per day (kg BOD <sub>5</sub> /person/day)	0.090
EF	= Emission factor (kg N <sub>2</sub> O-N/kg sewage-N discharged)	0.005
44/28	= Molecular weight ratio of N <sub>2</sub> O to N <sub>2</sub>	1.57
<i>F<sub>plant</sub></i>	= Fraction of nitrogen removed from the WWTP with nitrification/denitrification	0.7
365.25	= Conversion factor (day/year)	365.25
10 <sup>-3</sup>	= Conversion from kg to mt (mt/kg)	10 <sup>-3</sup>
GWP <sub>N<sub>2</sub>O</sub>	= Global Warming Potential; conversion from mt of N <sub>2</sub> O into mt of CO <sub>2</sub> equivalents	GWP <sup>69</sup>
Sample Calculation:		
Annual N <sub>2</sub> O emissions = ((10000 × 1.25) × (0.026 – 0.05 × 0.090) × 0.005 × 1.57 × (1 – 0.7) × 365.25 × 10 <sup>-3</sup> ) × 310		
= 7.17 mtCO <sub>2</sub> e		

- If the total N-load is known, it's acceptable for use. Equation WW.12.a should be utilized; this entails conducting Equation WW.12.(alt) with the exception of replacing the population served by WWTP (P), the factor for industrial or commercial discharge (*F<sub>ind-com</sub>*), the average total nitrogen per day (total N-load), the nitrogen uptake for cell growth (N uptake) and the amount

<sup>69</sup> See Appendix GWP for value.

of BOD<sub>5</sub> produced per person per day (BOD<sub>5</sub>) with the known average total nitrogen per load (total N-load).

Box WW.13<sub>CH4</sub> below gives an example of how to calculate attributed CH<sub>4</sub> emissions from a community.

**Box WW.13<sub>CH4</sub>**

**Example Calculation of attributed CH<sub>4</sub> emissions**

A entire community of 10,000 people is served by a centralized WWTP. This treatment plant serves a total population of 50,000 people and produces 500 mtCO<sub>2</sub>e in CH<sub>4</sub> a year. Based upon this scenario, the following inputs are as follows

Description		Value
Attributed CH <sub>4</sub> Emissions	= Annual CH <sub>4</sub> credited to the community (mtCO <sub>2</sub> e)	Result
P	= Population of the community served by the given WWTP	10,000
P <sub>tot</sub>	= Total population the WWTP serves	50,000
E	= Total CH <sub>4</sub> produced by WWTP (mtCO <sub>2</sub> e)	500

Sample Calculation:

$$\begin{aligned} \text{Attributed CH}_4 \text{ emissions} &= (10000/50000) * 500 \\ &= 100 \text{ mtCO}_2\text{e} \end{aligned}$$

- Equation WW.13<sub>N2O</sub> should be utilized to calculate the attributed N<sub>2</sub>O emissions. This entails conducting Equation WW.13<sub>CH4</sub> with the exception of replacing the population of community served by given WWTP (P), the total population the WWTP serves (P<sub>tot</sub>) and the total CH<sub>4</sub> produced by WWTP (E) with the scenario-specific factors.

Box WW.14 below gives an example of how to calculate the energy-related emissions from water supply and treatment from a community.

**Box WW.14**

**Energy-related Emissions from Water Distribution and Treatment**

The residential sector of a city in Indiana has a population of 50,000 people. Water is imported from outside this community. Assume default values to calculate the energy intensity of water extraction/conveyance, treatment and distribution.

Description		Value
Annual CO <sub>2</sub> e emissions	= Total annual emissions from water distribution and treatment	Result
Population	= Population in the community	50,000 people
per Capita Water Use	= Water use in gallons per day per capita from user supplied value or Table WW.14.1	145 gal/d/capita
Groundwater Supplied	= Fraction of the population served by groundwater from user supplied value or Table WW.14.1	0.39
Surface Water Supplied	= Fraction of the population served by surface water from user supplied value or Table WW.14.1	0.35
Groundwater Extraction Energy Intensity	= Electricity required to pump the groundwater from the water table depth to the surface from user supplied value or Table WW.14.2	540 kWh/MG
Water Conveyance Energy Intensity	= Electricity required to pump either groundwater or surface water from the source to the water treatment facility from user supplied value or Table WW.14.3	3000 kWh/MG
Daily Flow to Treatment Plant	= Average daily flow to the surface water treatment plant, needed if Table WW.14.4 is used	2.5 MGD
Surface Water Treatment Energy Intensity	= Electricity required to treat the water to drinking water standards either from user supplied value or Table WW.14.4	750 kWh/MG
Water Distribution Energy Intensity	= Electricity required to pump the treated groundwater or surface water from the treatment facility to the end user from user supplied value or Table WW.14.5	540 kWh/MG

Description		Value
Electricity Emission Factors	= Standard electricity emissions factors from eGRID (Table BE.10), or other verified source.	1,528.76 lb CO <sub>2</sub> eq./MWh (693.44 kg CO <sub>2</sub> eq./MWh)
10 <sup>-6</sup>	= Conversion from gallons to million gallons (MG/gal)	0.000001
10 <sup>-3</sup>	= Conversion from kWh to MWh (MWh/kWh)	0.001
10 <sup>-3</sup>	= Conversion from kg to MT (MT/kg)	0.001
<b><i>Annual CO<sub>2</sub>e Emissions= Extraction + Conveyance + Treatment + Distribution</i></b>		
Sample Calculation:		
<i>Annual Groundwater Extraction Emissions</i>	= (50,000 x 145 x 365.25 x 0.39 x 0.000001 x 540 x 693.44 x 0.001 x 0.001)	= <b>387 mtCO<sub>2</sub>e</b>
<i>Annual Groundwater and Surface Water Conveyance Supply Emissions</i>	= (50,000 x 145 x 365.25 x (0.39 + 0.35) x 0.000001 x 3000 x 693.44 x 0.001 x 0.001)	= <b>4073 mtCO<sub>2</sub>e</b>
<i>Annual Surface Water Treatment Emissions</i>	= (50,000 x 145 x 365.25 x 0.35 x 0.000001 x 750 x 693.44 x 0.001 x 0.001)	= <b>482 mtCO<sub>2</sub>e</b>
<i>Annual Groundwater and Surface Water Distribution Emissions</i>	= (50,000 x 145 x 365.25 x (0.39 + 0.35) x 0.000001 x 540 x 693.44 x 0.001 x 0.001)	= <b>737 mtCO<sub>2</sub>e</b>
<i>Total Emissions from Residential Water Consumption</i>	= 387 + 4073 + 482 + 737	= <b>5679 mtCO<sub>2</sub>e</b>

### Box WW.15 Example Calculation of Energy-Related Emissions from Wastewater Collection and Treatment

The residential sector of a city in Indiana has a population of 50,000 people. The community does not operate its own wastewater treatment nor does it have the resources to determine site-specific results. Assume default values to calculate the energy intensity of wastewater collection and treatment.

Description		Value
Annual CO <sub>2</sub> e emissions	= Total annual emissions from wastewater collection and treatment	Result
Population	= Population in the community	50,000 people
per Capita Wastewater Generation	= Wastewater generation in gallons per day per capita from user supplied value or Table WW.15.1	186 gal/d/capita
Centralized Percentage	= Fraction of the population served by all centralized systems from user supplied value or Table WW.15.1	0.84
Percentage Served by Lagoons	= Fraction of the population served by centralized lagoon or pond systems from user supplied value or Table WW.15.1	0.04
Percentage Served by Attached Growth	= Fraction of the population served by centralized trickling filters or rotating biological contactors from user supplied value or Table WW.15.1	0.12
Percentage Served by Conventional Activated Sludge	= Fraction of the population served by centralized conventional activated sludge systems from user supplied value or Table WW.15.1	0.58
Percentage Served by NDN	= Fraction served by centralized Nitrification or Nitrification/Denitrification activated sludge systems from user supplied value or Table WW.15.1	0.1

Process Energy Intensity for Wastewater Collection	= Electricity needed to convey untreated sewage from its various sources to a centralized treatment facility from user defined value or Table WW.15.2	280 kWh/MG
Process Energy Intensity for Wastewater Treatment by Lagoons	= Electricity needed to treat sewage to effluent standards by a centralized lagoon or pond from user defined value or Table WW.15.3	1150 kWh/MG
Process Energy Intensity for Wastewater Treatment by Attached Growth System	= Electricity needed to treat sewage to effluent standards by a centralized attached growth system from user defined value or Table WW.15.3	1500 kWh/MG
Process Energy Intensity for Wastewater Treatment by Conventional Activated Sludge Sample Calculation:	= Electricity needed to treat sewage to effluent standards by a centralized conventional activated sludge from user defined value or Table WW.15.3	2300 kWh/MG
<i>Annual Surface Supply Emissions</i>	= <b><i>mtCO<sub>2</sub>e</i></b>	
Process Energy Intensity for Wastewater Treatment by NDN	= Electricity needed to treat sewage to effluent standards by a centralized NDN plant from user defined value or Table WW.15.3	3300 kWh/MG
<i>Annual Groundwater Supply Emissions</i>	= <b><i>mtCO<sub>2</sub>e</i></b>	

**Sample Calculation:**

$$\begin{aligned} \text{Annual Collection Emissions} &= (50,000 \times 186 \times 365.25 \times 0.84 \times 0.000001 \times 280 \times \\ & 693.44 \times 0.001 \times 0.001) \\ &= \mathbf{558 \text{ mtCO}_2\text{e}} \end{aligned}$$

$$\begin{aligned} \text{Annual Wastewater Treatment} &= (50,000 \times 186 \times 365.25 \times 0.000001 \times ((0.04 \times 1150) + \\ \text{Emissions} & (0.12 \times 1500) + (0.58 \times 2300) + (0.1 \times 3300)) \times 693.44 \\ & \times 0.001 \times 0.001) \\ &= \mathbf{4,451 \text{ mtCO}_2\text{e}} \end{aligned}$$

$$\begin{aligned} \text{Total Emissions from Residential} &= 558 + 4451 \\ \text{Wastewater Management Water} & \\ \text{Consumption} &= \mathbf{5,300 \text{ mtCO}_2\text{e}} \end{aligned}$$